

Andrew S. Marcaccio, Counsel
PPL Services Corporation
AMarcaccio@pplweb.com

280 Melrose Street
Providence, RI 02907
Phone 401-784-4263



February 5, 2024

VIA ELECTRONIC MAIL

Luly E. Massaro, Commission Clerk
Rhode Island Public Utilities Commission
89 Jefferson Boulevard
Warwick, RI 02888

**RE: Docket No. 23-38-EL – The Narragansett Electric Company d/b/a
Rhode Island Energy’s Petition for Acceleration of a System Modification
Due to Distributed Generation Project
Weaver Hill Projects
Responses to Division Data Requests – Set 2**

Dear Ms. Massaro:

On behalf of The Narragansett Electric Company d/b/a Rhode Island Energy (the “Company”), enclosed please find the Company’s responses to the Division of Public Utilities and Carriers’ (“Division”) Second Set of Data Requests in the above-referenced docket.

Thank you for your attention to this filing. If you have any questions, please contact me at 401-784-4263.

Sincerely,

A handwritten signature in blue ink, appearing to read "Andrew S. Marcaccio".

Andrew S. Marcaccio

Enclosures

cc: Docket No. 23-38-EL Service List

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-1

Request:

Provide a CYME model with the solution for the Coventry 54F1 and Hopkins Hill 63F6 thermal issues being solved by the application of capacitors for optimum power factor correction.

Response:


A CYME model is included at Attachment DIV 2-1 with the power factor corrected to near unity on the Coventry 54F1 and Hopkins Hill 63F6.

For the 63F6, five capacitor banks were added to the model. Voltage and loading issues remain after the addition of the capacitor banks as shown in Figure 2-1-1 and 2-1-2.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-1, page 2


Figure 2-1-1 – 63F6 Loading After Power Factor Correction
(red indicates an overload)



The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-1, page 3

Figure 2-1-2 – 63F6 Voltage After Power Factor Correction
(yellow indicates low voltage)




For the 54F1, six capacitor banks were added in the model to correct the circuit to near unity power factor. No overloads were predicted before or after the capacitor bank additions. Voltage issues remain even with the new cap banks being added as shown in Figure 2-1-3.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-1, page 4

Figure 2-1-3 – 54F1 Voltage After Power Factor Correction
(yellow indicates low voltage)



The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-2

Request:

Provide a Table or circuit diagram showing the actual percent loading on peak during 2023 for Coventry 54F1 and Hopkins Hill 63F6. Also, provide the percent actual load growth for each of these feeders in 2021 and 2022 on the same table. Also, for each line section include the conductor size and maximum conductor capacity used to determine the percent loaded of the overloaded conductor sections.

Response:

Table 2-2-1 shows the actual percent loading on peak, element size, and rating for 2021, 2022, and 2023 for the Coventry 54F1 and Hopkins Hill 63F6.

Table 2-2-1 – Loading on 54F1 and 63F6 for 2021, 2022, and 2023

Substation	Feeder	SN Limiting Element	SN Amps	2021 Actual	2021 % SN	2022 Actual	2022 % SN	2023 Actual	2023 % SN
COVENTRY 54	54F1	Station Transformer	526	413	79%	402	76%	360*	68%
HOPKINS HILL 63	63F6	477 AL Spacer	530	483	91%	459	87%	409*	77%

*The 2023 peak occurred during September.

Division 2-3


Request:

Show on a circuit diagram for Coventry 54F1 and for Hopkins Hill 63F6 the portion of the feeder which is overloaded or loaded beyond 90 percent. Include the conductor size and ampacity of the conductor being used for the calculations.

Response:

Figure 2-3-1 is a circuit diagram for Hopkins Hill 63F6 showing the portion of the feeder which is overloaded or loaded beyond 90 percent. The conductor is 477 aluminum spacer cable, rated for 530 amps.

Figure 2-3-1 – 63F6 Section Loading Above 90%



There are no distribution line sections on the Coventry 54F1 loaded beyond 90%. The limiting element is the station transformer, which is loaded above 90%. Therefore, no diagram is provided.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-4

Request:

Provide a CYME model analysis for the Coventry 54F1 feeder and the Hopkins Hill 63F6 feeder for the projected loads five years after the initiation of the Impact Study and five years after the completion of the Impact Study assuming the distributed generation projected to be interconnected in the Weaver Hill Petition is not connected.

Response:

The Company cannot complete the request above because the distributed generation is connected to the 34.5kV supply for Nooseneck and Robin Hollow and will be connected to the 34.5kV supply for Studley. This has no impact on the two feeders.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-5

Request:

Provide for Coventry 54F1 and for Hopkins Hill 63F6, the number of hours each of the feeders' thermal capacity was exceeded and the number of hours the feeder reached or exceeded 90 percent of its thermal capacity. This should be provided for 2021, 2022 and 2023 and projected for each year from 2024 to 2035.

Response:

Table 2-5-1 shows the number of hours exceeding 100% and 90% for the Coventry 54F1 and Hopkins Hill 63F6 from 2021 to 2035.

Table 2-5-1 – 54F1 and 63F6 Hours of Loading

	54F1 100%	54F1 90%	63F6 100%	63F6 90%
2021	0	1	0	1
2022	0	0	0	0
2023	0	0	0	0
2024	0	1	1	4
2025	0	1	1	4
2026	0	1	1	5
2027	0	1	1	6
2028	0	1	1	6
2029	0	2	1	6
2030	0	3	1	6
2031	0	2	1	6
2032	0	1	1	6
2033	0	1	1	6
2034	0	1	1	5
2035	0	1	1	5

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-6

Request:

Provide the ampacity of the proposed 1,000 MCM UG conductor.

Response:

The generic rating for the 1,000 MCM copper cable is 535 amps. A specific rating will be developed using actual conditions during detailed design.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-7

Request:

Will the 1,000 MCM conductor exceed 90 percent loading during any N-1 contingencies? If so, provide the scenarios and a CYME model to indicate these conditions.

Response:

No, there are no N-1 contingencies that will cause the 1,000 MCM conductor to exceed 90 percent loading.

The Narragansett Electric Company
d/b/a Rhode Island Energy
RIPUC Docket No. 23-38-EL
In Re: Rhode Island Energy's Petition for Acceleration Due
To Distributed Generation Project – Weaver Hill Projects
Responses to the Division's Second Set of Data Requests
Issued on January 15, 2024

Division 2-8

Request:

Would a different sub-transmission/transmission voltage be utilized to serve Weaver Hill if the distribution generation projects were not installed? Please explain.


Response:

No, there are no other sub-transmission or transmission facilities in the area. The alternative considered in the Central Rhode Island West study was a more expensive sub-transmission option of the same voltage.

Certificate of Service

I hereby certify that a copy of the cover letter and any materials accompanying this certificate was electronically transmitted to the individuals listed below.

The paper copies of this filing are being hand delivered to the Rhode Island Public Utilities Commission and to the Rhode Island Division of Public Utilities and Carriers.



Joanne M. Scanlon

February 5, 2024
Date

Docket No. 23-38-EL Rhode Island Energy – Petition for Acceleration Due to DG Project – Weaver Hill Projects Service List updated 12/14/2023

Parties' Name/Address	E-mail	Phone
The Narragansett Electric Company d/b/a Rhode Island Energy Andrew Marcaccio, Esq. Celia B. O'Brien, Esq. 280 Melrose Street Providence, RI 02907	AMarcaccio@pplweb.com ;	401-784-7263
	COBrien@pplweb.com ;	
	JScanlon@pplweb.com ;	
	SBriggs@pplweb.com ;	
	KRCastro@RIEnergy.com ;	
	ERussell@RIEnergy.com ;	
Division of Public Utilities Margaret L. Hogan, Esq.	Leo.Wold@dpuc.ri.gov ;	
	Margaret.L.Hogan@dpuc.ri.gov ;	
	Christy.Hetherington@dpuc.ri.gov ;	
	John.bell@dpuc.ri.gov ;	
	Al.contente@dpuc.ri.gov ;	
	Paul.Roberti@dpuc.ri.gov ;	
	Ellen.golde@dpuc.ri.gov ;	
Gregory L. Booth, PLLC 14460 Falls of Neuse Rd. Suite 149-110 Raleigh, N. C. 27614	gboothpe@gmail.com ;	919-441-6440
Linda Kushner L. Kushner Consulting, LLC 514 Daniels St. #254 Raleigh, NC 27605	Lkushner33@gmail.com ;	919-810-1616
William Watson	wfwatson924@gmail.com ;	

Revity Energy LLC Nicholas L. Nybo, Esq. Revity Energy LLC & Affiliates 117 Metro Center Blvd., Suite 1007 Warwick, RI 02886	nick@revityenergy.com ;	508-269-6433
Green Development LLC Seth H. Handy, Esq. HANDY LAW, LLC 42 Weybosset Street Providence, RI 02903	seth@handylawllc.com ;	401-626-4839
Kevin Hirsch Green Development, LLC 2000 Chapel View Blvd, Suite 500 Cranston, RI 02920	kh@green-ri.com ; ms@green-ri.com ; hm@green-ri.com ; mu@green-ri.com ;	
File an original & 5 copies w/: Luly E. Massaro, Commission Clerk Public Utilities Commission 89 Jefferson Blvd. Warwick, RI 02888	Luly.massaro@puc.ri.gov ; Cynthia.WilsonFrias@puc.ri.gov ; Alan.nault@puc.ri.gov ; Todd.bianco@puc.ri.gov ; Kristen.L.Masse@puc.ri.gov ;	401-780-2107
Frank Epps, EDP	Frank@edp-energy.com ;	