

Substation Name	Total Connected DG MW (> 1MW)	Total Pending DG MW (> 1MW)	Total # of Pending Applications (> 1MW)	Total Connected + Pending DG MW (>1MW)	Potential Need for an ASO Study in next 6 months?	DG Penetration Level
ANTHONY SUBSTATION	0.2	0.0	0	0.2		<5MW
APPONAUG SUBSTATION	1.0	0.0	0	1.0		<5MW
BARRINGTON SUBSTATION	0.0	0.0	0	0.0		<5MW
BONNET SUBSTATION	0.2	0.0	0	0.2		<5MW
BRISTOL SUBSTATION	6.3	0.7	3	7.0		Between 5MW and 15MW
CHASE HILL SUBSTATION	23.3	18.8	6	42.2	YES	>15MW
CHOPMIST SUBSTATION	9.7	2.4	4	12.1		Between 5MW and 15MW
CLARKE STREET SUBSTATION	0.3	0.0	1	0.3		<5MW
CLARKSON STREET SUBSTATION	3.5	1.8	7	5.3		Between 5MW and 15MW
COVENTRY SUBSTATION	4.0	0.1	2	4.0		<5MW
DAVISVILLE SUBSTATION	14.2	0.0	0	14.2		Between 5MW and 15MW
DEXTER SUBSTATION	18.5	1.3	6	19.8		>15MW
DIVISION ST SUBSTATION	0.8	0.5	1	1.2		<5MW
DRUMROCK SUBSTATION	0.2	3.5	2	3.7		<5MW
DYER STREET SUBSTATION	0.2	0.1	1	0.2		<5MW
ELDERED SUBSTATION	0.2	0.0	0	0.2		<5MW
FARNUM PIKE SUBSTATION	13.7	5.1	2	18.9		>15MW
FARNUM SUBSTATION	0.1	0.0	0	0.1		<5MW
GATE TWO SUBSTATION	0.8	0.0	0	0.8		<5MW
HARRIS AVENUE SUBSTATION	0.4	0.0	0	0.4		<5MW
HARRISON SUBSTATION	0.0	0.0	0	0.0		<5MW
HIGHLAND PARK SUBSTATION SUBSTATION	7.0	1.5	2	8.5		Between 5MW and 15MW
HOPE SUBSTATION	0.4	3.5	1	3.9		<5MW
HOPKINS HILL SUBSTATION	13.2	4.9	4	18.1		>15MW
HOSPITAL SUBSTATION	0.0	0.0	0	0.0		<5MW
HUNTINGTON PARK SUBSTATION	0.1	0.0	0	0.1		<5MW
Iron Mine Substation	9.6	0.0	0	9.6		Between 5MW and 15MW
JEPSON SUBSTATION	17.4	19.0	3	36.4	YES	>15MW
JOHNSTON SUBSTATION	52.4	6.0	8	58.4	YES	>15MW
KENT COUNTY SUBSTATION	50.6	12.7	4	63.3	YES	>15MW
KENYON SUBSTATION	18.2	5.4	2	23.6	YES	>15MW
KILVERT ST. SUBSTATION	5.9	1.4	8	7.3		Between 5MW and 15MW
KNIGHTSVILLE SUBSTATION	0.1	0.2	2	0.3		<5MW
LAFAYETTE SUBSTATION	2.2	0.8	1	3.0		<5MW
LAKEWOOD SUBSTATION	0.0	0.0	0	0.0		<5MW
LANGWORTHY CORNER SUBSTATION	0.5	0.0	0	0.5		<5MW
LINCOLN AVENUE SUBSTATION	0.6	3.4	6	4.0		<5MW
LIPPITT HILL SUBSTATION	0.3	0.0	0	0.3		<5MW
MANTON SUBSTATION	0.4	0.0	0	0.4		<5MW
MINK STREET SUBSTATION	3.0	0.0	0	3.0		<5MW
NASONVILLE SUBSTATION	12.2	10.0	2	22.1	YES	>15MW
NATICK SUBSTATION	0.7	0.0	1	0.7		<5MW
NEW LONDON AVE SUBSTATION	2.3	0.2	2	2.6		<5MW
NORTH AQUIDNECK SUBSTATION	0.4	0.0	0	0.4		<5MW

OLD BAPTIST ROAD SUBSTATION	8.3	9.4	5	17.8		>15MW
OLNEYVILLE SUBSTATION	0.0	0.2	2	0.2		<5MW
Pawtucket SUBSTATION	5.8	1.1	4	6.9		Between 5MW and 15MW
PEACEDALE SUBSTATION	1.3	0.2	3	1.4		<5MW
PHILLIPSDALE SUBSTATION	0.2	0.3	1	0.5		<5MW
POINT STREET SUBSTATION	12.0	2.4	9	14.4		Between 5MW and 15MW
PONTIAC SUBSTATION	4.8	1.3	3	6.0		Between 5MW and 15MW
PUTNAM PIKE SUBSTATION	6.1	26.0	7	32.0	YES	>15MW
QUONSET SUBSTATION	1.7	41.1	8	42.8	YES	>15MW
RIVERSIDE SUBSTATION	5.1	0.4	2	5.5		Between 5MW and 15MW
SOUTH AQUIDNECK SUBSTATION	0.7	0.0	0	0.7		<5MW
SPRAGUE STREET SUBSTATION	0.1	0.0	0	0.1		<5MW
STAPLES SUBSTATION	6.3	5.4	9	11.7		Between 5MW and 15MW
TIOGUE AVE SUBSTATION	0.5	0.0	0	0.5		<5MW
TIVERTON SUBSTATION	10.2	1.3	9	11.5		Between 5MW and 15MW
TOWER HILL SUBSTATION	2.8	15.1	6	17.9		>15MW
VALLEY SUBSTATION	4.8	4.4	5	9.2		Between 5MW and 15MW
WAKEFIELD SUBSTATION	0.5	0.2	2	0.6		<5MW
WAMPANOAG SUBSTATION	5.1	1.3	2	6.4		Between 5MW and 15MW
WARREN SUBSTATION	11.1	0.3	2	11.3		Between 5MW and 15MW
WARWICK MALL SUBSTATION	0.1	0.0	0	0.1		<5MW
WASHINGTON SUBSTATION	11.8	6.4	13	18.2		>15MW
WATERMAN AVE SUBSTATION	0.9	0.3	1	1.2		<5MW
WEST CRANSTON SUBSTATION	23.4	6.3	2	29.7	YES	>15MW
WEST GREENVILLE SUBSTATION	0.1	0.0	0	0.1		<5MW
WEST HOWARD SUBSTATION	0.1	0.0	0	0.1		<5MW
WESTERLY SUBSTATION	0.4	0.4	3	0.8		<5MW
WICKFORD JUNCTION SUBSTATION	50.0	5.8	2	55.8	YES	>15MW
WOOD RIVER SUBSTATION	26.4	68.7	16	95.1	YES	>15MW
WOONSOCKET SUBSTATION	50.4	3.6	3	54.0	YES	>15MW