



60 Austin Street, Suite 301
Newton, MA 02460
(617) 409-7379
www.oaksquarepartners.com

VIA ELECTRONIC MAIL

March 13, 2026

Stephanie De La Rosa, Commission Clerk
Rhode Island Public Utilities Commission
89 Jefferson Boulevard
Warwick, RI 02888

RE: Docket No. 24-34-EL - Development of Tariffs Applicable to Energy Storage Systems Connected to the Electric Distribution Systems

Dear Ms. De La Rosa:

On behalf of Oak Square Partners (“OSP”), enclosed are OSP’s comments for filing in reference to Docket No. 24-34-EL. Our comments are in response to the Docket 24-34-EL Storage Workshop #16 presentation on March 5, 2026.

We appreciate the opportunity to comment.

Very Truly Yours,

A handwritten signature in blue ink that reads "John Typadis".

John Typadis
Principal
Oak Square Partners

Stakeholder Comments in Response to Docket 24-34-EL Storage Workshop #16 Presentation on March 5, 2026

- Issue #1: Eligibility – Rates
 - Trigger Point
 - BESS would apply for a reservation. ISA and site control needed to receive reservation.
 - Interconnection application is too low a threshold (propensity to use interconnection queue to box out other projects)
 - Need for permits is too high a threshold (too much development risk)
 - Once reservation confirmed, BESS would have 24-36 months to reach commercial operation (analogous to REGrowth Program).
 - Critical to have visibility of storage reservations so developers don't waste time chasing a reservation at same substation or on same feeder where there is only room for one project
 - Commercial Operation Date (COD – when BESS is energized and commercially operational) would start the clock on the rate eligibility term.
 - Term Structure – needs to be consistent and predictable. Rate re-evaluation every/every other rate case period would not provide consistency and predictability for financing.
 - Minimum – 10 years from COD
 - Target – 20 years from COD
 - Planning Cycle & Notice
 - Analogous to Clean Peak DCM – Utility should determine if an area is constrained (load- and/or generation-constrained) and also determine the kW/MW needed to solve the constraint. That amount should be shared with public.
 - Constraint will continue to exist if that amount of kW/MW is not installed/operating.
 - Constraint will not continue to exist if that amount of kW/MW is installed/operating.
 - Utility should evaluate the entire territory and define all constraints (load and generation)
 - What's Locked
 - Rate/Term
 - Constraint/Congestion Status
 - What Flexes
 - For predictability, rates would ideally not flex
 - Flexing rates amount to merchant rates, which are more difficult to finance

- Understanding that rates must flex through regular rate cases, we would suggest the following:
 - Rate floor – rates can go no lower than this level – provides some certainty
 - Rate cases at extended intervals: every 5 years/7years/10 years (if possible)
 - Setting rates during rate cases with predictable steps up or steps down
 - Setting rates during rate cases for terms longer than rate case cycle (e.g., if rate case is every 5 years, set rates for next 10 years)
 - Rates would apply to a BESS reservation date
 - Size
 - Minimum: none
 - Maximum: 5-10 MW
 - Issue #2: Defining Constrained Locations
 - Utility should be clear about constraints being load-driven or generation-driven and provide proper value signal
 - Utility should be clear if they want both types of constraints solved or one type of constraint solved more than the other type of constraint
 - Should also be clear what the rates are to solve each type of constraint
 - Level
 - System level congestion should be measured at feeder and substation level
 - OK if each level has a different value signal
 - Threshold Type
 - Absolute
 - Data & Metric
 - Both load-driven and generation-driven
 - Issue #3: Rate Design and Cost Allocation
 - Charge Side
 - Time-of-Use – Off-peak, Peak, Super Peak (adjusted for season)
 - Discharge Side
 - Time-of-Use and
 - Demand-based
 - Credit should reflect value to reducing overall system/substation/feeder demand
 - Issue #4: Constrained Location Value Signal
 - Additional Value Signals
 - Location – Constrained or not constrained

- Time of Day – Peak, Super Peak, “Clean Peak” (e.g., Massachusetts – high levels of solar generation)
 - Resiliency – if paired with solar or helps alleviate issues of strong solar generation
 - Mechanism
 - Feeder/Substation multipliers – for load, generation, or both
- Issue #5: Program Alignment
 - Proposed Complementary Stacking Rate Structure
 - System Rate (base rate)
 - Constrained Rate Adder (load or generation or both)
 - Time of Day Rate Adder
 - Resiliency Adder (if with solar or on a feeder/at a substation with strong solar generation)
 - For consideration
 - Eligibility for stand-alone BESS to participate in Connected Solutions
 - Stand-alone BESS should be eligible to participate so long as they are not being double-compensated and
 - E.g., can received Connected Solutions PBI but not Time-of-Use rate while performing in Connected Solutions
 - Important to avoid redundant stacking