

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS  
PUBLIC UTILITIES COMMISSION

THE NARRAGANSETT ELECTRIC :  
COMPANY d/b/a NATIONAL GRID, :  
Plaintiff, :

v. :  
:

THE TOWN OF HOPKINTON; THOMAS :  
E. BUCK; SYLVIA THOMPSON; :  
BARBARA CAPALBO; BEVERLY :  
KENNEY; and WILLIAM FELKNER, in :  
their official capacities as members of the :  
Hopkinton Town Council, :  
Defendants. :

and

Docket No. 4076

THE NARRAGANSETT ELECTRIC :  
COMPANY d/b/a NATIONAL GRID, :  
Plaintiff, :

v. :  
:

THE TOWN OF HOPKINTON and BRAD :  
R. WARD, in his official capacity as the :  
Building and Zoning Official of the Town :  
of Hopkinton, :  
Defendants. :

**PREFILED TESTIMONY OF ALAN T. LABARRE, P.E.**  
**ON BEHALF OF THE NARRAGANSETT ELECTRIC COMPANY**  
**D/B/A NATIONAL GRID**

September 24, 2009

1 Q. Please state your name and business address.

2 A. My name is Alan T. LaBarre. My business address is 40 Sylvan Road, Waltham,  
3 Massachusetts.

4 Q. By whom are you employed and in what position?

5 A. I am employed by National Grid USA Service Company as Manager of Capacity Planning  
6 in the Network Asset Planning Department.

7 Q. What are your responsibilities as Manager of Capacity Planning?

8 A. I am responsible for assigning, prioritizing, reviewing, and approving the work performed  
9 by engineers whose principal function is assessing the performance and planning the  
10 development of National Grid's electrical distribution infrastructure. My functional  
11 responsibility in this regard includes the New England and upstate New York service  
12 territory of National Grid.

13 Q. Please describe your education, training, and experience.

14 A. I have a Bachelor of Science Degree in Electrical Engineering from the University of Rhode  
15 Island. I am also a graduate of the Worcester Polytechnic Institute's School of Industrial  
16 Management. I am a registered Professional Engineer in the State of Rhode Island. I have  
17 21 years of professional experience in the area of electrical distribution infrastructure  
18 planning at National Grid. During the first 12 years of this experience (1988 – 2000), I was  
19 directly responsible for the execution of area distribution system planning studies within the  
20 central and southeastern portions of National Grid's Massachusetts service territory. Over  
21 the remaining 9 years (2000 – present), I have managed engineering groups either  
22 responsible for the completion of area distribution planning reviews or the development of  
23 tools and analysis procedures used by planning engineers. These managerial positions were:

1           Manager of District Engineering for the Southeast District of Massachusetts Electric from  
2           1/2000 – 5/2002, Manager of Distribution Planning and Engineering for The Narragansett  
3           Electric Company from 5/2002 - 4/2004, Manager of System Planning and Engineering for  
4           National Grid USA Service Company from 4/2004 - 4/2005, Manager of Network Planning  
5           and Reliability for National Grid USA Service Company from 4/2005 – 7/2008, and  
6           Manager of Capacity Planning from 7/2008 - present.

7    Q.    Have you previously testified before the PUC or the EFSB?

8    A.    Yes. I provided testimony before the PUC and the EFSB on the need for and benefits  
9           related to the development of National Grid’s Tower Hill substation located in North  
10          Kingstown, RI. These proceedings took place in 2006.

11   Q.    Are you familiar with National Grid’s proposed new substation in Hopkinton, Rhode Island  
12          (the “Project”)?

13   A.    Yes, I am familiar with the Project.

14   Q.    What is the scope of your testimony in this proceeding?

15   A.    I will summarize the planning process by which National Grid identifies the need for  
16          electrical distribution system infrastructure development and describe the specific Study  
17          Area in which the Project is located. I will also explain the benefit of the Project to electric  
18          customers and explain how the Project was selected as the proper alternative among other  
19          options and why those alternatives are not viable. Finally, I will also explain the distribution  
20          circuit (feeder) system improvements that will be made as part of the Project.

21   Q.    Please describe the process by which National Grid determines that distribution system  
22          improvements are necessary.

1 A. The Annual Capacity Plan is the primary means used to identify existing and long range  
2 needs of the distribution system and to recommend infrastructure development solutions that  
3 will provide reliable and economic electric delivery service to National Grid customers. The  
4 Annual Capacity Plan process reviews the electric infrastructure within specific geographic  
5 areas (Study Areas). The Annual Capacity Plan presently identifies distribution system  
6 infrastructure development requirements required to address facility loading concerns that  
7 are projected to occur within the next five years.

8 When conducting the Annual Capacity Planning process, Power Supply Area (PSA)  
9 forecasts, published by the National Grid Energy Portfolio Management Department, are  
10 used to project annual loads in the Study Area for the study period. To complement the PSA  
11 forecasts, the Study Area historical annual load growth rate is calculated and anticipated  
12 large spot loads are identified. Taking all these variables into consideration, annual peak  
13 loads are projected for all distribution feeders, distribution supply lines (sub-transmission  
14 lines), and substation supply transformers within a Study Area.

15 After distribution system loads are projected, we perform diagnostic analysis of  
16 equipment loading and system voltage performance, under both normal and contingency  
17 conditions. Service reliability is assessed to identify existing and anticipated problems. If  
18 the existing infrastructure is inadequate or will become inadequate before the end of the  
19 review period, infrastructure improvement plans are developed to resolve the area problems.  
20 The plans that are developed consider the establishment of new facilities and/or the  
21 expansion of existing facilities.

22 Q. Please describe the Study Area and geographic area to which the Project relates and why a  
23 comprehensive plan is required.

1 A. The South County West Study Area encompasses the towns of Charlestown, Hopkinton,  
2 Richmond, Westerly, and the western section of South Kingstown. The Study Area has  
3 approximately 31,000 customers with a summer peak load of approximately 95 MW. A  
4 comprehensive plan is required to address multiple existing and projected feeder,  
5 transformer, and distribution supply line loading issues in the Study Area.

6 Q. What need was identified in the South County West Study Area?

7 A. The 2007 Annual Capacity Plan first identified a number of thermal overloading concerns in  
8 the South County West Study Area and recommended the new Hopkinton substation to  
9 address these concerns. In its most recent update, the 2009 Annual Capacity Plan reaffirmed  
10 the extent of overloading concerns in the South County West Study Area. These concerns  
11 include one transformer and four feeders projected to be loaded above their summer normal  
12 rating. In addition to normal loading concerns, three transformers and two distribution  
13 supply lines are projected to exceed their summer emergency ratings. The 2009 Annual  
14 Capacity Plan incorporates the latest forecasts including the consequences of the recent  
15 economic downturn which we are experiencing.

16 Q. What does this mean for customers?

17 A. Maximum loading of electrical equipment is determined by National Grid and expressed as  
18 normal ratings or normal capabilities. This is the maximum loading considered acceptable  
19 for the equipment under normal operating conditions. Emergency ratings or capabilities are  
20 the maximum equipment loading considered acceptable during system contingency  
21 operations. These ratings are applied for relatively short periods of time, generally less than  
22 24 hours.

1           The concerns identified in the 2009 Annual Capacity Plan indicate that electric  
2           system equipment loading is approaching normal capabilities and exceeds emergency  
3           capabilities during system contingencies at many locations. If equipment loading above  
4           capability is left unaddressed, it can lead to customer service interruptions resulting from  
5           equipment failure. To prevent equipment failure due to load in excess of capability, system  
6           operators may be required to interrupt service to certain customers during peak system load  
7           periods. In addition, heavily loaded equipment also reduces the flexibility system operators  
8           have to rearrange the distribution system during outages resulting from other causes such as  
9           tree contact with overhead lines, wind storm damage, motor vehicle pole hits, etc. When  
10          system operators cannot rearrange the distribution system to bypass damaged facilities,  
11          customer service restoration must wait until system repairs are made. Restoration of service  
12          via system rearrangement can typically be completed within 2-4 hours while restoration that  
13          must wait for system repairs can often take between 4-24 hours. It is also important to note  
14          that with equipment loading approaching normal capabilities it becomes more difficult to  
15          serve new customers in a timely, economic, and reliable manner.

16    Q.    Please identify the specific transformers, feeders and other equipment that are projected to  
17          exceed their normal or emergency ratings.

18    A.    Attached as attachments ATL-1 through 3 are listings of projected normal and contingency  
19          peak loads on all South County West Study Area distribution feeders, substation supply  
20          transformers and distribution supply lines, respectively, from the 2009 Annual Capacity  
21          Plan.

22          The projected system overloads of greatest concern are as follows:

- 1       • Existing peak loading on the Wood River transformer T10 exceeds and is projected to
- 2           continue to exceed summer emergency rating in 2009 and beyond for the loss of the
- 3           larger Wood River transformer T20 on peak.
- 4       • Existing peak loading on Westerly transformers T2 and T4 exceeds and is projected to
- 5           continue to exceed summer emergency rating in 2009 for the loss of either transformer
- 6           on peak.
- 7       • Loading on Ashaway transformer T1 is projected to exceed summer normal rating in
- 8           2015.
- 9       • Loading on Westerly feeders 16F1 and 16F2 is projected to exceed summer normal
- 10          ratings by 2012.
- 11       • Loading on Kenyon feeder 42F1 is projected to exceed summer normal ratings by 2014.
- 12       • Loading on Ashaway feeder 43F1 is projected to exceed summer normal rating by 2015.
- 13       • Loading on Wood River supply line 85T2 is projected to exceed summer emergency
- 14          rating by 2009 for the loss of either supply line 85T3 or Westerly transformer T4 on
- 15          peak.
- 16       • Loading on Wood River supply line 85T3 is projected to exceed summer emergency
- 17          rating by 2011 for the loss of either supply line 85T2 or Westerly transformer T2 on
- 18          peak.
- 19   Q.   How do overloads on transformers in Westerly and feeders in Charlestown affect customers
- 20          in Hopkinton?
- 21   A.   The electrical system is operated as an interconnected grid and customers in Hopkinton and
- 22          other towns are served from facilities that are projected to be overloaded. The existing
- 23          distribution system in the area is shown in Att. ATL-4. Operational response to system

1 contingencies will include actions up to and including load shed (customer service  
2 interruptions) to prevent equipment damage and a wide area outage. This load shedding for  
3 a contingency would affect customers in Hopkinton as well as Charlestown and Westerly.

4 Q. What system operational problems could these thermal concerns result in?

5 A. Loss of the largest Wood River transformer on peak could result in unserved customer load  
6 of approximately 11 MVA in 2009 (growing to 20 MVA in 2015). Loss of either Westerly  
7 transformer on peak could result in unserved customer load of approximately 5 MVA in  
8 2009 (growing to 12 MVA in 2015).

9 In the event the contingencies described occur, the operational response would be to install a  
10 mobile transformer to restore customer service. A conservative (not less than) estimate of  
11 the time required to install a mobile transformer is 24 hours. Furthermore, available mobile  
12 transformers do not have the same capabilities to regulate system voltage as the permanently  
13 installed units at Wood River substation. As such, system voltage performance concerns  
14 (which result in customer equipment operation problems) could remain even after customer  
15 service is restored.

16 Q. What solution did the Annual Capacity Plan identify for these problems?

17 A. The Annual Capacity Plan identified a need for new supply and distribution capacity. The  
18 Annual Plan recommended the installation of a new 115/12.47 kV substation and three  
19 distribution feeders in Hopkinton, Rhode Island. The site selected is land owned by The  
20 Narragansett Electric Company on Route 3 adjacent to an existing electric transmission line  
21 and right of way.

22 Q. Please explain the alternative that was considered.

1 A. The alternative considered the reinforcement and expansion of the existing 34.5 kV supply  
2 and 12.47 kV distribution system. It included the replacement of both Westerly  
3 transformers; the replacement of the smaller Wood River Supply transformer; development  
4 (capacity increases and reconfiguration) of the Westerly 16F4, 16F5 and 16F6 feeders; and  
5 upgrades to the Wood River supply lines.

6 Q. What is the conclusion of your analysis?

7 A. The development of a new 115/12.47 kV substation on Route 3 in Hopkinton is the  
8 recommended plan. The recommended plan is superior to the alternative plan because it  
9 introduces new distribution capacity in a location where load is developing and where there  
10 is ready access to the existing distribution and transmission systems. The recommended  
11 plan provides much needed capacity to relieve heavily loaded distribution and supply  
12 circuits and improves customer service reliability in Hopkinton. As an added benefit, the  
13 recommended plan results in the retirement and removal of Ashaway substation. Ashaway  
14 is a small single feeder substation built in 1972 and supplied off the 34.5 kV distribution  
15 supply system. This substation is not suitable for expansion to address the Study Area  
16 concerns identified in the Annual Capacity Plan and will eventually require replacement of  
17 aged and outdated equipment. The condition of the substation's feeder circuit breaker was  
18 recently reviewed and it has been recommended for replacement. In addition, the  
19 conceptual estimated cost of the alternate plan exceeds twice that of the recommended plan.  
20 The alternative plan would reinforce existing supply and distribution capacity to sufficiently  
21 address existing and projected loading concerns. However, should significant, presently  
22 unanticipated, spot loads develop along Route 3, it would be more difficult and costly to  
23 serve this load without the proposed substation. The alternative plan only delays the need

1 for new supply and distribution capacity in the vicinity of the existing transmission right of  
2 way in Hopkinton. The Company would have to return in the future with a new proposal to  
3 serve load growth in and around this area.

4 Q. Mr. LaBarre, how will the Hopkinton substation project solve these concerns?

5 A. The installation of a new 115/12.47 kV substation and three distribution feeders will resolve  
6 area transformer, feeder, and supply line overloads. New distribution feeders will support  
7 the retirement of Ashaway substation, relief of Wood River and Westerly substations, relief  
8 of the distribution supply system, and relief of area feeders. The reconfigured distribution  
9 supply system following construction of the Hopkinton Substation is shown in Att. ATL-5.

10 Q. What will these benefits mean for consumers?

11 A. The benefits are a more reliable electric system that should experience fewer outages than  
12 the existing system and one that will require significantly less time to restore when system  
13 contingencies do occur. The introduction of a new 115 kV source will allow for the capacity  
14 to support load growth and customer expansion in the Town of Hopkinton.

15 Q. Does this complete your testimony?

16 A. Yes, it does.

ATTACHMENTS

- ATL-1 2009 Annual Plan Feeder Problem Identification Spreadsheet – South County West Study Area
- ATL-2 2009 Annual Plan Transformer Problem Identification Spreadsheet – South County West Study Area
- ATL-3 2009 Annual Plan Supply Line Problem Identification Spreadsheet – South County West Study Area
- ATL-4 Existing Supply Areas & Distribution Feeders, Hopkinton, RI
- ATL-5 Proposed Supply Areas & Distribution Feeders, Hopkinton, RI

# 2009 Annual Plan Feeder Problem Identification Spreadsheet

South County West Study Area

Substation	Voltage (kV)	Feeder	Normal Limiting Element	Normal Element Specifics	SN Rating (Amps)	Emergency Limiting Element	Emergency Element Specifics	SE Rating (Amps)	Projected Load													
									2009		2010		2011		2012		2013		2014		2015	
									Amps	% SN	Amps	% SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
ASHAWAY 43	12.47	43F1	Transformer	5.0/6.25 MVA	388	Transformer	5.0/6.25 MVA	423	324	83%	333	86%	345	89%	359	93%	371	96%	381	98%	390	100%
HOPE VALLEY 41	12.47	41F1	Transformer	5.0 MVA	347	Transformer	5.0 MVA	430	253	73%	260	75%	270	78%	281	81%	290	84%	298	86%	305	88%
KENYON 68	12.47	68F1	UG Cable	1C 1000AI XLPE DB	512	Relay/Fuse	612 Amp Safe Carry	612	359	70%	369	72%	383	75%	398	78%	412	80%	422	82%	432	84%
KENYON 68	12.47	68F2	UG Cable	1C 1000AI XLPE DB	511	Relay/Fuse	612 Amp Safe Carry	612	370	72%	380	74%	394	77%	410	80%	424	83%	435	85%	445	87%
KENYON 68	12.47	68F3	UG Cable	1C 1000AI XLPE DB	512	OH Line	336.4 AI (TULIP) Bare	515	442	86%	454	89%	471	92%	490	96%	506	99%	519	101%	531	104%
KENYON 68	12.47	68F4	UG Cable	1C 1000AI XLPE DB	514	Relay/Fuse	612 Amp Safe Carry	612	264	51%	272	53%	282	55%	293	57%	303	59%	311	60%	318	62%
KENYON 68	12.47	68F5	Relay/Fuse	612 Amp Safe Carry	612	Relay/Fuse	612 Amp Safe Carry	612	286	47%	294	48%	305	50%	317	52%	327	54%	336	55%	344	56%
LANGWORTHY CORNER 86	12.47	86F1	Transformer	5.6/7 MVA	382	Transformer	5.6/7 MVA	429	308	81%	317	83%	328	86%	342	89%	353	92%	362	95%	371	97%
WESTERLY 16	12.47	16F1	OH Line	336.4 AI (TULIP) Bare	515	OH Line	336.4 AI (TULIP) Bare	515	478	93%	492	95%	510	99%	530	103%	548	106%	562	109%	575	112%
WESTERLY 16	12.47	16F2	OH Line	336.4 AI (TULIP) Bare	515	OH Line	336.4 AI (TULIP) Bare	515	467	91%	480	93%	498	97%	518	101%	535	104%	549	107%	562	109%
WESTERLY 16	12.47	16F3	OH Line	336.4 AI (TULIP) Bare	515	OH Line	336.4 AI (TULIP) Bare	515	385	75%	396	77%	411	80%	427	83%	441	86%	452	88%	463	90%
WESTERLY 16	12.47	16F4	OH Line	477 AI (COSMOS) Bare	645	OH Line	477 AI (COSMOS) Bare	645	262	41%	270	42%	280	43%	291	45%	300	47%	308	48%	316	49%

# 2009 Annual Plan Transformer Problem Identification Spreadsheet

South County West Study Area

Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Load										Projected Contingency																	
		From	To		SN	SE	2009		2010		2011		2012		2013		2014		2015		2009		2010		2011		2012		2013		2014		2015	
							MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SE														
ASHAWAY 43	1	34.5	12.47	6.3	8.4	9.1	7.0	83%	7.2	86%	7.5	89%	7.8	92%	8.0	95%	8.2	98%	8.4	100%	7.0	77%	7.2	79%	7.5	82%	7.8	85%	8.0	88%	8.2	90%	8.4	92%
HOPE VALLEY 41	1	34.5	12.47	5.0	7.3	9.3	5.5	75%	5.6	78%	5.8	80%	6.1	84%	6.3	86%	6.4	89%	6.6	91%	5.5	59%	5.6	61%	5.8	63%	6.1	65%	6.3	67%	6.4	69%	6.6	71%
KENYON 68	1	115	12.47	40.0	49.7	53.7	22.3	45%	22.9	46%	23.8	48%	24.7	50%	25.5	51%	26.2	53%	26.8	54%	35.6	66%	36.6	68%	37.9	71%	39.5	73%	40.8	76%	41.8	78%	42.8	80%
KENYON 68	2	115	12.47	40.0	49.7	53.7	13.3	27%	13.7	27%	14.2	29%	14.7	30%	15.2	31%	15.6	31%	16.0	32%	35.6	66%	36.6	68%	37.9	71%	39.5	73%	40.8	76%	41.8	78%	42.8	80%
LANGWORTHY 86	1	34.5	12.47	5.6	8.2	9.3	6.7	81%	6.8	83%	7.1	86%	7.4	90%	7.6	92%	7.8	95%	8.0	97%	6.7	72%	6.8	74%	7.1	77%	7.4	80%	7.6	82%	7.8	84%	8.0	86%
WESTERLY 16	2	34.5	12.47	20.0	25.6	26.7	18.1	71%	18.6	73%	19.3	75%	20.1	78%	20.7	81%	21.3	83%	21.8	85%	31.8	120%	32.7	123%	34.0	127%	35.3	132%	36.5	137%	37.4	140%	38.3	144%
WESTERLY 16	4	34.5	12.47	20.0	25.6	26.7	15.4	60%	15.9	62%	16.5	64%	17.1	67%	17.7	69%	18.1	71%	18.6	73%	31.8	120%	32.7	123%	34.0	127%	35.3	132%	36.5	137%	37.4	140%	38.3	144%
WOOD RIVER 85	10	115	34.5	40.0	48.2	52.4	39.0	81%	39.6	82%	40.5	84%	41.5	86%	42.3	88%	43.0	89%	43.6	91%	63.3	121%	64.6	123%	66.4	127%	68.4	130%	70.2	134%	71.6	136%	72.9	139%
WOOD RIVER 85	20	115	34.5	80.0	91.2	106.6	24.3	27%	25.0	27%	25.9	28%	27.0	30%	27.9	31%	28.6	31%	29.3	32%	63.3	59%	64.6	61%	66.4	62%	68.4	64%	70.2	66%	71.6	67%	72.9	68%

# 2009 Annual Plan Supply Line Problem Identification Spreadsheet

South County West Study Area

Circuit	Voltage (kV)	Limiting Element	Element Specifics	Line Section		Rating (MVA)		Projected Load														Projected Contingency										Worst Contingency				
								2009		2010		2011		2012		2013		2014		2015		2009		2010		2011		2012		2013			2014		2015	
								MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SE	MVA	%SE	MVA	%SE	MVA	%SE	MVA	%SE		MVA	%SE	MVA	%SE
85T1	34.5	Recloser	560A	Terminal Equipment		35.8	38.5	10.5	29%	10.6	30%	10.8	30%	11.1	31%	11.3	31%	11.4	32%	11.6	32%	30.1	78%	30.5	79%	30.9	80%	31.4	82%	31.8	83%	32.2	84%	32.5	84%	85T3 OOS
85T1	34.5	UG Cable	750 Al	Wood River	P174 Riser	30.7	43.9	10.5	34%	10.6	35%	10.8	35%	11.1	36%	11.3	37%	11.4	37%	11.6	38%	30.1	69%	30.5	69%	30.9	70%	31.4	72%	31.8	73%	32.2	73%	32.5	74%	85T3 OOS
85T1	34.5	OH Line	795 Al	P174 Riser	Hope Valley	53.2	53.2	10.5	20%	10.6	20%	10.8	20%	11.1	21%	11.3	21%	11.4	21%	11.6	22%	30.1	57%	30.5	57%	30.9	58%	31.4	59%	31.8	60%	32.2	60%	32.5	61%	85T3 OOS
85T1	34.5	OH Line	477 Al Spca	P174 Riser	Hope Valley	29.8	36.6	10.5	35%	10.6	36%	10.8	36%	11.1	37%	11.3	38%	11.4	38%	11.6	39%	30.1	82%	30.5	83%	30.9	84%	31.4	86%	31.8	87%	32.2	88%	32.5	89%	85T3 OOS
85T1	34.5	OH Line	336.4 Al	P174 Riser	Hope Valley	32.6	32.6	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	5.0	15%	SN
85T2	34.5	Recloser	560A	Terminal Equipment		35.8	38.5	25.1	70%	25.8	72%	26.7	75%	27.8	78%	28.7	80%	29.5	82%	30.2	84%	39.3	102%	40.4	105%	41.9	109%	43.6	113%	45.0	117%	46.2	120%	47.3	123%	Westerly T4/85T3 OOS
85T2	34.5	UG Cable	2-1000 Cu	Wood River	PTR P070	53.0	76.0	25.1	47%	25.8	49%	26.7	50%	27.8	52%	28.7	54%	29.5	56%	30.2	57%	39.3	52%	40.4	53%	41.9	55%	43.6	57%	45.0	59%	46.2	61%	47.3	62%	Westerly T4/85T3 OOS
85T2	34.5	OH Line	795 Al	Wood River	PTR P070	53.2	53.2	25.1	47%	25.8	48%	26.7	50%	27.8	52%	28.7	54%	29.5	55%	30.2	57%	39.3	74%	40.4	76%	41.9	79%	43.6	82%	45.0	85%	46.2	87%	47.3	89%	Westerly T4/85T3 OOS
85T2	34.5	Recloser	800A - VSA	PTR P070		47.8	50.2	25.1	52%	25.8	54%	26.7	56%	27.8	58%	28.7	60%	29.5	62%	30.2	63%	33.5	67%	34.5	69%	35.7	71%	37.2	74%	38.4	76%	39.4	78%	40.3	80%	Westerly T4/85T3 OOS
85T2	34.5	OH Line	795 Al	PTR P070	Westerly	53.2	53.2	25.1	47%	25.8	48%	26.7	50%	27.8	52%	28.7	54%	29.5	55%	30.2	57%	33.5	63%	34.5	65%	35.7	67%	37.2	70%	38.4	72%	39.4	74%	40.3	76%	Westerly T4/85T3 OOS
85T3	34.5	Bus conductor	500 Cu	Terminal Equipment		53.9	58.3	34.9	65%	35.4	66%	36.2	67%	37.1	69%	37.9	70%	38.5	71%	39.1	73%	51.4	88%	52.4	90%	53.9	92%	55.5	95%	56.9	97%	58.0	99%	59.1	101%	Westerly T2/85T2 OOS
85T3	34.5	UG Cable	2-1000 Cu	Wood River	Langworthy Tap	53.0	76.0	34.9	66%	35.4	67%	36.2	68%	37.1	70%	37.9	72%	38.5	73%	39.1	74%	51.4	68%	52.4	69%	53.9	71%	55.5	73%	56.9	75%	58.0	76%	59.1	78%	Westerly T2/85T2 OOS
85T3	34.5	OH Line	795 Al	Wood River	Langworthy Tap	53.2	53.2	34.9	66%	35.4	67%	36.2	68%	37.1	70%	37.9	71%	38.5	72%	39.1	74%	51.4	97%	52.4	99%	53.9	101%	55.5	104%	56.9	107%	58.0	109%	59.1	111%	Westerly T2/85T2 OOS
85T3	34.5	OH Line	477 Al	Langworthy Tap	PTR P137-50	38.5	38.5	21.3	55%	21.4	56%	21.7	56%	22.0	57%	22.2	58%	22.4	58%	22.6	59%	21.3	55%	21.4	56%	21.7	56%	22.0	57%	22.2	58%	22.4	58%	22.6	59%	SN
85T3	34.5	Recloser	RVE Recloser	PTR P137-50		23.9	23.9	21.3	89%	21.4	90%	21.7	91%	22.0	92%	22.2	93%	22.4	94%	22.6	95%	21.3	89%	21.4	90%	21.7	91%	22.0	92%	22.2	93%	22.4	94%	22.6	95%	SN
85T3	34.5	OH Line	477 Al	PTR P137-50	PTR P17	38.5	38.5	21.3	55%	21.4	56%	21.7	56%	22.0	57%	22.2	58%	22.4	58%	22.6	59%	21.3	55%	21.4	56%	21.7	56%	22.0	57%	22.2	58%	22.4	58%	22.6	59%	SN
85T3	34.5	Recloser	RVE Recloser	PTR P17		23.9	23.9	6.7	28%	6.8	29%	7.1	30%	7.4	31%	7.6	32%	7.8	33%	8.0	33%	6.7	28%	6.8	29%	7.1	30%	7.4	31%	7.6	32%	7.8	33%	8.0	33%	SN
85T3	34.5	OH Line	477 Al	PTR P17	Langworthy Sub	38.5	38.5	6.7	17%	6.8	18%	7.1	18%	7.4	19%	7.6	20%	7.8	20%	8.0	21%	6.7	17%	6.8	18%	7.1	18%	7.4	19%	7.6	20%	7.8	20%	8.0	21%	SN
85T3	34.5	OH Line	795 Al	Langworthy Tap	PTR P136	53.2	53.2	15.4	29%	15.9	30%	16.5	31%	17.1	32%	17.7	33%	18.1	34%	18.6	35%	32.5	61%	33.4	63%	34.7	65%	36.1	68%	37.2	70%	38.2	72%	39.1	74%	Westerly T2/85T2 OOS
85T3	34.5	Recloser	800A - VSA	PTR P136		47.8	50.2	15.4	32%	15.9	33%	16.5	34%	17.1	36%	17.7	37%	18.1	38%	18.6	39%	32.5	65%	33.4	67%	34.7	69%	36.1	72%	37.2	74%	38.2	76%	39.1	78%	Westerly T2/85T2 OOS
85T3	34.5	O/H Line	795 Al	PTR P136	Westerly Sub	53.2	53.2	15.4	29%	15.9	30%	16.5	31%	17.1	32%	17.7	33%	18.1	34%	18.6	35%	32.5	61%	33.4	63%	34.7	65%	36.1	68%	37.2	70%	38.2	72%	39.1	74%	Westerly T2/85T2 OOS


# Existing Supply Areas & Distribution Feeders

## Hopkinton, Rhode Island

- Legend**
- Town Boundary
  - Existing 16F1 Feeder
  - Existing 16F2 Feeder
  - Existing 16F3 Feeder
  - Existing 16F3 Feeder
  - Existing 41F1 Feeder
  - Existing 43F1 Feeder
  - Existing 63F6 Feeder
  - Existing 68F3 Feeder
  - Existing 68F4 Feeder
  - Existing 85T1 Feeder
  - Existing 85T2 Feeder
  - Existing 85T3 Feeder
  - Existing 86F1 Feeder

**34.5kV Supply Area**  
Needs Relief

**Sources:**  
Land Features (GIS Data) Obtained from RIGIS, 2009  
Distribution Feeder Information Obtained from National Grid, 2009




**PUC Dkt. No. 4076**  
**Attachment ATL-4**

# Proposed Supply Areas & Distribution Feeders

## Hopkinton, Rhode Island

- Legend**
- Town Boundary
  - Existing 16F1 Feeder
  - Existing 16F2 Feeder
  - Existing 16F3 Feeder
  - Existing 16F3 Feeder
  - Existing 41F1 Feeder
  - Existing 63F6 Feeder
  - Existing 68F3 Feeder
  - Existing 68F4 Feeder
  - Existing 85T1 Feeder
  - Existing 85T2 Feeder
  - Existing 85T3 Feeder
  - Existing 86F1 Feeder
  - Proposed F1 Feeder
  - Proposed F3 Feeder
  - Proposed F5 Feeder

Sources:  
 Land Features (GIS Data) Obtained from RIGIS, 2009  
 Distribution Feeder Information Obtained from National Grid, 2009



PUC Dkt. No. 4076  
 Attachment ATL-5