



January 18, 2017

The Hon. Jorge O. Elorza
Mayor

Ricky Caruolo
General Manager

Mrs. Luly Massaro
Commission Clerk
RI Public Utilities Commission
89 Jefferson Boulevard
Warwick, RI 02888

BOARD OF DIRECTORS

Xaykham Khamsyvoravong
Chairperson

Joseph D. Cataldi
Vice Chairperson

Michael J. Correia
Councilperson

Sabina Matos
Councilperson

Lawrence J. Mancini
Ex-Officio

Cristen L. Raucci, Esq.
Member

Kerri Lynn Thurber
Member

Carissa R. Richard
Secretary

William E. O'Gara, Esq.
Legal Advisor

RE: Dk 4618: Kent County, Set 3-Update

Dear Mrs. Massaro:

Enclosed please find an original and nine copies of Providence Water's updated response to KCWA 3-1 originally filed on January 11, 2017.

If you have any questions I can be reached extension 7217.

Sincerely,

Mary L. Deignan-White
Senior Manager of Regulatory

cc: service list(via email)

MEMBER

Rhode Island Water Works Assn.
New England Water Works Assn.
American Water Works Assn.
Water Research Foundation

An EPA WaterSense Partner

(401) 521-6300

552 Academy Avenue
Providence, RI 02908

www.provwater.com

Follow us @provwater

Like us at:
facebook.com/Providencewater

Providence Water Docket 4618

Data Requests of the Kent County Water Authority Set 3

KCWA 3-1: Regarding Mr. Giasson's rebuttal testimony, page 4, please provide the testing schedule for each size retail meter and for the wholesale meters. Please provide a summary of the meter testing results over the past four years for each size retail meter and for the wholesale meters.

Response: Providence Water makes every effort to have all large meters (3" above) tested within a two year period and every effort to have the wholesale meters tested yearly. Retail meters are replaced on at least an every 20 year cycle. This schedule of testing/replacement complies with the Periodic Meter Testing schedule set forth in the Division of Public Utilities and Carriers Rules and Regulations Prescribing Standards for Water Utilities. In addition, each wholesale meter as well as our large retail meters are monitored each month for consumption patterns.

If the meter does not meet AWWA standards (98.5%-101.5%) we will replace the meter or change out the (UME) Unitized measuring element. See attached for meter testing results.

Update: In original response filed on January 11, 2017 meter testing results for meters 2" and below were not included because PW only test if there is a dispute or a final reading looks peculiar. The "DR" means that the meter did not register 100% for that particular test. Attached are the results of meter testing on all meters 2" and below.

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
1/14/2017	810885	5/8"	100%	100%	100%
12/22/2016	421064	5/8"	100%	100%	100%
12/22/2016	317269	1.5"	100%	100%	100%
12/22/2016	117035	5/8"	100%	100%	100%
12/19/2016	152011	5/8"	100%	100%	100%
12/19/2016	323199	5/8"	100%	100%	100%
12/15/2016	802716	5/8"	100%	100%	100%
12/15/2016	802716	5/8"	100%	100%	100%
12/5/2016	321406	1"	100%	100%	100%
11/28/2016	351077	5/8"	100%	100%	100%
11/23/2016	428202	2"	100%	100%	100%
11/21/2016	438118	5/8"	100%	100%	100%
11/16/2016	505022	5/8"	100%	100%	100%
11/15/2016	356191	5/8"	100%	100%	100%
11/15/2016	803531	5/8"	100%	100%	100%
11/9/2016	245092	3/4"	100%	100%	100%
11/9/2016	813083	3/4"	100%	100%	100%
11/2/2016	242276	1"	100%	100%	100%
11/2/2016	814259	1"	DR		
10/27/2016	127288	2"	100%	100%	100%
10/27/2016	431055	5/8"	100%	100%	100%
10/27/2016	102324	3/4"	100%	100%	100%
10/27/2016	308232	5/8"	100%	100%	100%
10/21/2016	251268	1"	100%	100%	100%
10/21/2016	510028	2"	100%	100%	100%
10/21/2016	145127	3/4"	100%	100%	100%
10/19/2016	252035	5/8"	100%	100%	100%
10/19/2016	150073	5/8"	100%	100%	100%
10/19/2016	354174	5/8"	100%	100%	100%
10/19/2016	346054	5/8"	100%	100%	100%
10/19/2016	302063	5/8"	100%	100%	100%
10/19/2016	134102	5/8"	100%	100%	100%
10/19/2016	219020	2"	100%	100%	100%
10/19/2016	242072	1"	100%	100%	100%
10/17/2016	813980	3/4"	100%	100%	100%
10/17/2016	801796	3/4"	100%	100%	100%
10/11/2016	133226	5/8"	100%	100%	100%
10/11/2016	245097	5/8"	100%	100%	100%
10/11/2016	358231	5/8"	100%	100%	100%
10/11/2016	252059	5/8"	100%	100%	100%
10/5/2016	252016	5/8"	100%	100%	100%
9/28/2016	815315	5/8"	100%	100%	100%
9/23/2016	436050	3/4"	100%	100%	100%
9/21/2016	439009	5/8"	100%	100%	100%
9/19/2016	227021	5/8"	DR		
9/12/2016	344235	5/8"	100%	100%	100%
9/1/2016	360121	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
8/26/2016	127286	5/8"	DR		
8/26/2016	106016	5/8"	100%	100%	100%
8/26/2016	102042	5/8"	DR		
8/26/2016	309088	3/4"	100%	100%	100%
8/23/2016	802181	5/8"	100%	100%	100%
8/23/2016	335068	5/8"	100%	100%	100%
8/19/2016	104015	5/8"	100%	100%	100%
8/17/2016	367110	5/8"	DR		
8/17/2016	802960	5/8"	100%	100%	100%
8/15/2016	126008	5/8"	DR		
8/15/2016	417021	5/8"	100%	100%	100%
8/12/2016	815644	1"	100%	100%	100%
8/3/2016	229121	3/4"	100%	100%	100%
8/3/2016	219027	5/8"	100%	100%	100%
8/3/2016	802757	5/8"	100%	100%	100%
8/3/2016	457154	5/8"	100%	100%	100%
7/27/2016	253108	5/8"	100%	100%	100%
7/26/2016	102342	1"	100%	100%	100%
7/26/2016	802725	3/4"	100%	100%	100%
7/26/2016	151170	5/8"	100%	100%	100%
7/26/2016	466098	5/8"	100%	100%	100%
7/26/2016	219014	3/4"	100%	100%	100%
7/21/2016	323089	5/8"	100%	100%	100%
7/20/2016	346030	5/8"	100%	100%	100%
7/14/2016	321026	1"	100%	100%	100%
7/12/2016	111048	5/8"	100%	100%	100%
7/8/2016	253228	5/8"	100%	100%	100%
7/8/2016	365239	5/8"	100%	100%	100%
7/8/2016	816489	3/4"	100%	100%	100%
7/1/2016	440083	5/8"	100%	100%	100%
7/1/2016	335190	5/8"	100%	100%	100%
6/29/2016	122251	5/8"	DR		
6/29/2016	354122	5/8"	DR		
6/29/2016	125108	5/8"	DR		
6/28/2016	156100	5/8"	100%	100%	100%
6/28/2016	455130	5/8"	100%	100%	100%
6/28/2016	447097	5/8"	DR		
6/24/2016	810498	5/8"	100%	100%	100%
6/24/2016	246228	5/8"	DR		
6/24/2016	103307	1"	100%	100%	100%
6/24/2016	210075	5/8"	DR		
6/22/2016	810706	5/8"	100%	100%	100%
6/22/2016	107100	5/8"	100%	100%	100%
6/22/2016	120062	5/8"	DR		
6/20/2016	435039	5/8"	100%	100%	100%
6/20/2016	416197	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
6/20/2016	347079	5/8"	100%	100%	100%
6/17/2016	368025	5/8"	100%	100%	100%
6/15/2016	457168	2"	100%	100%	100%
6/14/2016	147195	5/8"	100%	100%	100%
6/14/2016	803839	5/8"	100%	100%	100%
6/9/2016	329181	5/8"	100%	100%	100%
6/9/2016	218327	5/8"	100%	100%	100%
6/7/2016	363028	5/8"	100%	100%	100%
6/7/2016	129003	5/8"	100%	100%	100%
6/7/2016	463076	5/8"	DR		
5/31/2016	215066	5/8"	100%	100%	100%
5/31/2016	324285	1"	100%	100%	100%
5/23/2016	417131	5/8"	100%	100%	100%
5/18/2016	812655	5/8"	100%	100%	100%
5/18/2016	415034	5/8"	100%	100%	100%
5/18/2016	202121	5/8"	100%	100%	100%
5/18/2016	469007	5/8"	100%	100%	100%
5/12/2016	102337	1"	100%	100%	100%
3/31/2016	226029	5/8"	100%	100%	100%
3/31/2016	461146	5/8"	100%	100%	100%
3/31/2016	367239	2"	100%	100%	100%
3/31/2016	110111	5/8"	100%	100%	100%
3/28/2016	104096	5/8"	100%	100%	100%
3/28/2016	157052	5/8"	100%	100%	100%
3/28/2016	111244	5/8"	DR		
3/28/2016	354168	5/8"	100%	100%	100%
3/28/2016	814294	5/8"	100%	100%	100%
3/28/2016	120273	1"	DR		
3/28/2016	319311	5/8"	100%	100%	100%
3/23/2016	153219	3/4"	100%	100%	100%
3/23/2016	345194	5/8"	100%	100%	100%
3/23/2016	110264	5/8"	100%	100%	100%
3/23/2016	311258	5/8"	100%	100%	100%
3/23/2016	804147	5/8"	100%	100%	100%
3/23/2016	814780	3/4"	100%	100%	100%
3/18/2016	354228	5/8"	DR		
3/18/2016	803751	5/8"	DR		
3/18/2016	120128	5/8"	100%	100%	100%
3/18/2016	152221	5/8"	100%	100%	100%
3/18/2016	358010	5/8"	100%	100%	100%
3/11/2016	348125	3/4"	100%	100%	100%
3/11/2016	334038	3/4"	100%	100%	100%
3/11/2016	435200	3/4"	DR		
3/10/2016	467027	5/8"	100%	100%	100%
3/10/2016	311288	5/8"	100%	100%	100%
3/10/2016	431171	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
3/10/2016	422015	5/8"	DR		
3/9/2016	462059	5/8"	100%	100%	100%
3/8/2016	431012	5/8"	100%	100%	100%
3/8/2016	133085	5/8"	DR		
3/8/2016	336159	5/8"	DR		
3/8/2016	431022	5/8"	100%	100%	100%
3/8/2016	802330	5/8"	100%	100%	100%
3/7/2016	501142	2"	DR		
3/7/2016	243152	2"	100%	100%	100%
3/7/2016	241199	3/4"	DR		
3/2/2016	814290	3/4"	100%	100%	100%
3/2/2016	208165	5/8"	DR		
3/2/2016	321068	1"	100%	100%	100%
3/2/2016	410159	5/8"	100%	100%	100%
3/2/2016	244222	3/4"	DR		
3/1/2016	318044	1.5"	100%	100%	100%
2/29/2016	156262	1"	DR		
2/25/2016	452218	5/8"	100%	100%	100%
2/25/2016	220261	1.5"	DR		
2/24/2016	135158	5/8"	DR		
2/24/2016	413076	3/4"	100%	100%	100%
2/24/2016	434084	5/8"	DR		
2/24/2016	232127	5/8"	DR		
2/24/2016	455008	5/8"	100%	100%	100%
2/24/2016	305073	3/4"	100%	100%	100%
2/22/2016	446011	3/4"	100%	100%	100%
2/17/2016	251008	5/8"	100%	100%	100%
2/9/2016	452129	5/8"	100%	100%	100%
2/9/2016	245024	5/8"	DR		
2/3/2016	342233	5/8"	DR		
2/3/2016	350149	5/8"	100%	100%	100%
2/3/2016	334037	5/8"	100%	100%	100%
2/3/2016	231229	3/4"	DR		
2/1/2016	352067	5/8"	100%	100%	100%
2/1/2016	147141	5/8"	100%	100%	100%
1/27/2016	248022	5/8"	100%	100%	100%
1/27/2016	817204	5/8"	100%	100%	100%
1/27/2016	402040	3/4"	100%	100%	100%
1/27/2016	133237	5/8"	100%	100%	100%
1/27/2016	246165	5/8"	100%	100%	100%
1/27/2016	801808	5/8"	100%	100%	100%
1/27/2016	410223	5/8"	100%	100%	100%
1/27/2016	426245	1.5"	100%	100%	100%
1/14/2016	802637	5/8"	100%	100%	100%
1/14/2016	104193	5/8"	DR		
1/14/2016	204090	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
1/14/2016	349230	5/8"	100%	100%	100%
1/14/2016	332007	3/4"	100%	100%	100%
1/14/2016	816028	5/8"	100%	100%	100%
1/12/2016	110180	5/8"	100%	100%	100%
1/12/2016	113149	5/8"	DR		
1/12/2016	402302	1.5"	100%	100%	100%
1/8/2016	220212	5/8"	100%	100%	100%
1/8/2016	343095	5/8"	100%	100%	100%
1/8/2016	231212	5/8"	DR		
1/8/2016	356034	3/4"	100%	100%	100%
1/6/2016	362037	5/8"	100%	100%	100%
1/6/2016	224024	5/8"	100%	100%	100%
1/5/2016	248163	5/8"	100%	100%	100%
1/4/2016	329222	5/8"	100%	100%	100%
12/31/2015	814409	5/8"	DR		
12/31/2015	455017	1"	DR		
12/23/2015	452182	5/8"	100%	100%	100%
12/23/2015	359239	5/8"	100%	100%	100%
12/22/2015	422265	5/8"	100%	100%	100%
12/22/2015	426142	3/4"	100%	100%	100%
12/18/2015	127050	5/8"	100%	100%	100%
12/17/2015	810181	5/8"	DR		
12/17/2015	802945	5/8"	100%	100%	100%
12/15/2015	231263	5/8"	DR		
12/15/2015	504059	1"	100%	100%	100%
12/15/2015	356194	5/8"	100%	100%	100%
12/11/2015	146073	1"	DR		
12/11/2015	360257	1"	100%	100%	100%
12/11/2015	149135	5/8"	100%	100%	100%
12/11/2015	465155	5/8"	DR		
12/11/2015	401054	5/8"	100%	100%	100%
12/11/2015	253032	5/8"	100%	100%	100%
12/11/2015	143193	5/8"	100%	100%	100%
12/11/2015	351203	5/8"	100%	100%	100%
12/1/2015	327201	5/8"	100%	100%	100%
11/23/2015	407059	5/8"	100%	100%	100%
11/18/2015	801538	5/8"	100%	100%	100%
11/18/2015	357215	5/8"	DR		
11/18/2015	317230	5/8"	100%	100%	100%
11/18/2015	114148	5/8"	100%	100%	100%
11/18/2015	124221	5/8"	DR		
11/18/2015	410224	5/8"	100%	100%	100%
11/18/2015	248152	5/8"	DR		
11/18/2015	223099	5/8"	100%	100%	100%
11/18/2015	126182	5/8"	100%	100%	100%
11/17/2015	120260	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
11/17/2015	811543	5/8"	100%	100%	100%
11/17/2015	135230	5/8"	100%	100%	100%
11/16/2015	248189	5/8"	100%	100%	100%
11/16/2015	456160	5/8"	100%	100%	100%
11/16/2015	362025	5/8"	100%	100%	100%
11/13/2015	803080	5/8"	100%	100%	100%
11/13/2015	305070	5/8"	100%	100%	100%
11/13/2015	453248	5/8"	100%	100%	100%
11/12/2015	103262	5/8"	DR		
11/12/2015	249123	5/8"	DR		
11/12/2015	248110	5/8"	DR		
11/10/2015	814587	3/4"	DR		
11/9/2015	249014	5/8"	DR		
11/9/2015	203149	5/8"	100%	100%	100%
11/9/2015	138063	5/8"	100%	100%	100%
11/5/2015	803734	5/8"	100%	100%	100%
11/5/2015	814968	5/8"	100%	100%	100%
11/5/2015	114133	5/8"	100%	100%	100%
11/5/2015	114155	3/4"	100%	100%	100%
11/5/2015	446062	5/8"	100%	100%	100%
11/5/2015	431144	5/8"	100%	100%	100%
11/5/2015	445061	5/8"	100%	100%	100%
11/5/2015	460017	3/4"	DR		
11/3/2015	219311	2"	100%	100%	100%
11/3/2015	212197	5/8"	100%	100%	100%
11/3/2015	219062	5/8"	100%	100%	100%
11/3/2015	226039	5/8"	100%	100%	100%
11/3/2015	433049	5/8"	DR	DR	DR
11/2/2015	348109	5/8"	100%	100%	100%
10/28/2015	151151	5/8"	100%	100%	100%
10/28/2015	223095	5/8"	100%	100%	100%
10/28/2015	416077	5/8"	100%	100%	100%
10/27/2015	132024	2"	DR		
10/27/2015	240230	5/8"	DR		
10/27/2015	147232	5/8"	100%	100%	100%
10/27/2015	311154	5/8"	100%	100%	100%
10/27/2015	208196	5/8"	DR		
10/26/2015	119251	5/8"	100%	100%	100%
10/26/2015	136246	5/8"	100%	100%	100%
10/26/2015	816573	5/8"	100%	100%	100%
10/23/2015	358156	5/8"	100%	100%	100%
10/23/2015	114058	5/8"	DR		
10/22/2015	433174	5/8"	100%	100%	100%
10/22/2015	414140	3/4"	100%	100%	100%
10/22/2015	126204	5/8"	100%	100%	100%
10/22/2015	433084	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
10/19/2015	126164	5/8"	100%	100%	100%
10/19/2015	248106	5/8"	DR		
10/19/2015	126156	5/8"	DR		
10/19/2015	369252	1.5"	100%	100%	100%
10/19/2015	236055	1"	100%	100%	100%
10/19/2015	429244	5/8"	100%	100%	100%
10/19/2015	207192	5/8"	100%	100%	100%
10/15/2015	463087	5/8"	DR		
10/14/2015	810864	5/8"	100%	100%	100%
10/9/2015	466233	5/8"	100%	100%	100%
10/9/2015	312206	5/8"	DR		
10/8/2015	336174	3/4"	DR		
10/5/2015	149001	5/8"	100%	100%	100%
10/5/2015	109078	5/8"	DR		
10/2/2015	434213	5/8"	DR		
10/2/2015	127114	5/8"	100%	100%	100%
10/2/2015	302051	5/8"	100%	100%	100%
9/30/2015	418266	3/4"	DR		
9/30/2015	203512	1"	100%	100%	100%
9/30/2015	201188	5/8"	100%	100%	100%
9/30/2015	802165	5/8"	100%	100%	100%
9/30/2015	811774	1"	100%	100%	100%
9/30/2015	317026	5/8"	DR		
9/30/2015	334144	5/8"	100%	100%	100%
9/24/2015	127077	5/8"	100%	100%	100%
9/24/2015	469052	5/8"	100%	100%	100%
9/24/2015	115014	5/8"	100%	100%	100%
9/23/2015	332249	5/8"	DR		
9/23/2015	433185	5/8"	100%	100%	100%
9/23/2015	443244	5/8"	DR		
9/16/2015	318123	5/8"	100%	100%	100%
9/16/2015	309159	5/8"	100%	100%	100%
9/16/2015	242230	5/8"	100%	100%	100%
9/16/2015	817113	5/8"	100%	100%	100%
9/16/2015	109173	5/8"	100%	100%	100%
9/15/2015	419133	5/8"	100%	100%	100%
9/14/2015	810002	1"	100%	100%	100%
9/10/2015	419133	5/8"	DR	DR	DR
9/10/2015	438250	5/8"	DR	DR	DR
9/10/2015	433216	5/8"	100%	100%	100%
9/10/2015	115008	5/8"	DR	DR	DR
9/3/2015	227130	1"	DR	DR	DR
9/3/2015	304277	5/8"	100%	100%	100%
9/3/2015	327128	3/4"	100%	100%	100%
9/1/2015	432169	5/8"	100%	100%	100%
8/31/2015	463184	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
8/31/2015	140083	5/8"	100%	100%	100%
8/27/2015	246229	5/8"	DR	DR	DR
8/27/2015	433080	5/8"	100%	100%	100%
8/27/2015	127123	5/8"	DR	DR	DR
8/26/2015	311134	5/8"	100%	100%	100%
8/26/2015	363221	5/8"	DR	DR	DR
8/26/2015	329287	3/4"	DR	DR	DR
8/26/2015	151236	5/8"	100%	100%	100%
8/25/2015	702125	5/8"	DR	DR	DR
8/24/2015	127005	5/8"	100%	100%	100%
8/24/2015	247230	5/8"	100%	100%	100%
8/24/2015	403097	5/8"	100%	100%	100%
8/20/2015	354185	5/8"	100%	100%	100%
8/19/2015	250243	5/8"	100%	100%	100%
8/19/2015	346036	5/8"	100%	100%	100%
8/19/2015	115219	5/8"	DR	DR	DR
8/13/2015	218154	5/8"	DR	DR	DR
8/13/2015	208155	5/8"	100%	100%	100%
8/13/2015	817370	5/8"	100%	100%	100%
8/12/2015	230156	5/8"	DR	DR	DR
8/12/2015	423070	3/4"	100%	100%	100%
8/12/2015	144086	5/8"	100%	100%	100%
8/12/2015	427192	5/8"	100%	100%	100%
8/5/2015	438014	5/8"	DR		
8/5/2015	427020	5/8"	100%	100%	100%
7/31/2015	226027	5/8"	DR		
7/31/2015	367214	5/8"	DR		
7/31/2015	433089	5/8"	DR	100%	100%
7/31/2015	225062	5/8"	DR		
7/31/2015	814544	1"	100%	100%	100%
7/28/2015	317016	5/8"	100%	100%	100%
7/28/2015	301050	5/8"	DR		
7/28/2015	225110	5/8"	100%	100%	100%
7/24/2015	243175	1"	100%	100%	100%
7/24/2015	357253	3/4"	100%	100%	100%
7/23/2015	106115	5/8"	100%	100%	100%
7/23/2015	701913	1"	100%	100%	100%
7/17/2015	357071	5/8"	DR		
7/17/2015	412251	3/4"	DR	100%	100%
7/14/2015	232129	5/8"	DR		
7/1/2015	431004	5/8"	DR		
7/1/2015	321057	5/8"	100%	100%	100%
7/1/2015	358179	3/4"	100%	100%	100%
6/30/2015	402230	5/8"	100%	100%	100%
6/26/2015	139164	5/8"	100%	100%	100%
6/26/2015	360139	3/4"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
6/19/2015	335201	5/8"	DR	DR	DR
6/19/2015	253280	3/4"	100%	100%	100%
6/18/2015	360108	5/8"	DR	DR	DR
6/18/2015	816862	5/8"	100%	100%	DR
6/16/2015	365072	5/8"	DR	DR	DR
6/15/2015	119200	5/8"	DR	DR	DR
6/12/2015	510029	2"	100%	100%	100%
6/9/2015	251122	5/8"	100%	100%	100%
6/9/2015	461045	5/8"	100%	100%	100%
6/4/2015	241020	3/4"	DR	DR	DR
6/4/2015	207014	5/8"	DR	DR	DR
6/4/2015	114028	5/8"	100%	100%	100%
6/4/2015	462161	5/8"	100%	100%	100%
6/2/2015	811388	5/8"	100%	100%	100%
6/2/2015	132079	5/8"	DR	DR	DR
6/2/2015	207045	5/8"	100%	100%	100%
6/1/2015	242005	5/8"	100%	100%	100%
5/28/2015	209110	5/8"	100%	100%	100%
5/28/2015	307331	3/4"	100%	100%	100%
5/20/2015	242228	5/8"	100%	100%	100%
5/20/2015	701259	2"	100%	100%	100%
5/18/2015	367190	5/8"	100%	100%	100%
5/18/2015	126234	5/8"	100%	100%	100%
5/9/2015	140160	5/8"	100%	100%	100%
5/8/2015	330080	3/4"	DR	DR	DR
5/8/2015	811767	3/4"	DR	DR	DR
5/8/2015	103179	5/8"	100%	100%	100%
5/8/2015	817252	3/4"	100%	100%	100%
5/7/2015	154013	3/4"	DR	DR	DR
5/7/2015	335218	5/8"	100%	100%	100%
5/6/2015	334129	5/8"	100%	100%	100%
5/5/2015	402316	5/8"	DR	DR	DR
5/1/2015	103053	5/8"	DR	DR	DR
4/29/2015	232026	5/8"	100%	100%	100%
4/29/2015	153144	5/8"	100%	100%	100%
4/29/2015	316318	3/4'	100%	100%	100%
4/29/2015	456012	5/8"	100%	100%	100%
4/29/2015	420244	5/8"	DR	DR	DR
4/29/2015	366214	5/8"	100%	100%	100%
4/29/2015	439012	5/8"	100%	100%	100%
4/29/2015	332030	5/8"	DR	DR	DR
4/29/2015	812433	3/4"	100%	100%	100%
4/29/2015	455191	5/8"	DR	DR	DR
4/28/2015	251249	1"	100%	100%	100%
4/24/2015	701257	2"	100%	100%	100%
4/24/2015	233277	1"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
4/23/2015	800843	5/8"	100%	100%	100%
4/23/2015	347210	5/8"	100%	100%	100%
4/23/2015	354132	5/8"	100%	100%	100%
4/23/2015	334065	5/8"	100%	100%	100%
4/23/2015	360208	5/8"	DR	DR	DR
4/23/2015	814084	5/8"	DR	DR	DR
4/23/2015	103240	5/8"	100%	100%	100%
4/23/2015	211086	5/8"	100%	100%	100%
4/20/2015	464282	5/8"	DR	DR	DR
4/20/2015	464023	5/8"	100%	100%	100%
4/20/2015	132114	5/8"	100%	100%	100%
4/20/2015	462005	3/4"	DR	DR	DR
4/20/2015	344133	5/8"	100%	100%	100%
4/17/2015	435072	5/8"	100%	100%	100%
4/17/2015	367046	5/8"	100%	100%	100%
4/17/2015	224240	5/8"	100%	100%	100%
4/17/2015	203213	5/8"	DR	DR	DR
4/17/2015	144041	5/8"	DR	DR	DR
4/17/2015	425053	5/8"	100%	100%	100%
4/17/2015	369043	5/8"	100%	100%	100%
4/16/2015	425208	1"	DR	DR	DR
4/16/2015	415233	3/4"	100%	100%	100%
4/16/2015	241254	1"	DR	100%	100%
4/15/2015	701990	3/4"	100%	100%	100%
4/8/2015	335135	1"	100%	100%	100%
4/7/2015	332108	5/8"	100%	100%	100%
4/7/2015	802900	5/8"	DR	DR	DR
4/7/2015	139255	5/8"	DR	DR	DR
4/7/2015	228200	5/8"	DR	DR	DR
4/7/2015	448213	5/8"	100%	100%	100%
4/7/2015	468053	5/8"	100%	100%	100%
4/1/2015	802492	5/8"	100%	100%	100%
3/30/2015	457155	5/8"	100%	100%	100%
3/30/2015	137213	3/4"	DR	DR	DR
3/30/2015	350002	5/8"	100%	100%	100%
3/30/2015	509097	2"	DR	DR	DR
3/30/2015	212106	5/8"	100%	100%	100%
3/24/2015	132013	1"	100%	100%	100%
3/24/2015	338174	5/8"	100%	100%	100%
3/24/2015	223150	5/8"	DR	DR	DR
3/24/2015	463271	1"	DR	100%	100%
3/24/2015	464258	5/8"	100%	100%	100%
3/23/2015	410235	5/8"	100%	100%	100%
3/23/2015	801956	5/8"	100%	100%	100%
3/23/2015	148068	5/8"	100%	100%	100%
3/23/2015	350040	5/8"	DR	DR	DR

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
3/18/2015	319007	5/8"	DR	DR	DR
3/18/2015	816347	5/8"	DR	DR	DR
3/18/2015	152100	5/8"	DR	DR	DR
3/18/2015	409067	5/8"	DR	DR	DR
3/18/2015	453132	5/8"	100%	100%	100%
3/16/2015	248147	5/8"	100%	100%	100%
3/16/2015	146120	5/8"	100%	100%	100%
3/16/2015	438057	5/8"	100%	100%	100%
3/16/2015	412234	5/8"	DR	DR	DR
3/16/2015	802521	5/8"	100%	100%	100%
3/16/2015	816752	5/8"	DR	DR	DR
3/16/2015	103266	3/4"	DR	DR	DR
3/12/2015	816124	5/8"	DR	DR	DR
3/12/2015	202123	5/8"	100%	100%	100%
3/12/2015	466243	5/8"	DR	DR	DR
3/9/2015	406188	5/8"	DR	DR	DR
3/6/2015	247188	5/8"	DR	DR	DR
3/6/2015	353254	1"	100%	100%	100%
3/6/2015	353254	1"	100%	100%	100%
3/5/2015	800637	2"	DR	DR	DR
3/5/2015	218080	1"	100%	100%	100%
3/4/2015	335235	2"	100%	100%	100%
3/4/2015	248267	5/8"	100%	100%	100%
3/4/2015	121098	5/8"	DR	DR	DR
3/4/2015	409224	5/8"	100%	100%	100%
3/3/2015	233006	3/4"	100%	100%	100%
3/3/2015	115066	1"	DR	100%	100%
3/2/2015	810733	5/8"	100%	100%	100%
3/2/2015	342204	5/8"	DR	DR	DR
2/25/2015	468058	5/8"	100%	100%	100%
2/25/2015	459010	5/8"	100%	100%	100%
2/25/2015	103072	5/8"	DR	DR	DR
2/23/2015	104136	5/8"	DR	DR	DR
2/23/2015	248175	5/8"	100%	100%	100%
2/23/2015	359230	5/8"	100%	100%	100%
2/19/2015	413026	5/8"	100%	100%	100%
2/11/2015	409033	5/8"	100%	100%	100%
2/9/2015	457139	5/8"	100%	100%	100%
2/9/2015	432138	5/8"	100%	100%	100%
2/5/2015	224009	5/8"	DR	DR	DR
2/5/2015	801921	5/8"	100%	100%	100%
2/3/2015	413264	5/8"	DR	DR	DR
2/3/2015	356229	5/8"	100%	100%	100%
2/3/2015	432216	5/8"	DR	DR	DR
2/3/2015	419220	5/8"	DR	DR	DR
2/3/2015	202501	1"	DR	DR	DR

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
2/2/2015	248029	1"	100%	100%	100%
2/2/2015	101064	5/8"	100%	100%	100%
2/2/2015	363176	5/8"	DR	DR	DR
2/2/2015	140146	5/8"	100%	100%	100%
2/2/2015	800717	5/8"	100%	100%	100%
2/2/2015	432189	5/8"	100%	100%	100%
2/2/2015	353167	5/8"	100%	100%	100%
1/26/2015	340068	5/8"	100%	100%	100%
1/26/2015	136096	5/8"	DR	DR	DR
1/26/2015	125022	5/8"	DR	DR	DR
1/22/2015	335229	1"	100%	100%	100%
1/22/2015	449022	5/8"	DR	DR	DR
1/22/2015	125020	5/8"	DR	DR	DR
1/22/2015	146217	5/8"	100%	100%	100%
1/22/2015	131089	3/4"	100%	100%	100%
1/20/2015	327277	5/8"	100%	100%	100%
1/20/2015	468087	5/8"	100%	100%	100%
1/16/2015	701877	3/4"	DR	DR	DR
1/15/2015	802783	1"	100%	100%	100%
1/14/2015	424048	1"	100%	100%	100%
1/14/2015	817488	5/8"	100%	100%	100%
1/12/2015	432058	5/8"	DR	DR	DR
1/12/2015	421059	5/8"	100%	100%	100%
1/6/2015	461011	5/8"	100%	100%	100%
1/6/2015	803838	5/8"	DR	DR	DR
1/6/2015	323263	1"	100%	100%	100%
1/6/2015	104198	5/8"	DR	DR	DR
12/30/2014	312055	5/8"	DR	DR	DR
12/30/2014	102062	5/8"	DR	DR	DR
12/30/2014	132169	5/8"	DR	DR	DR
12/23/2014	322129	5/8"	100%	100%	100%
12/23/2014	368180	5/8"	100%	100%	100%
12/23/2014	801975	5/8"	DR	DR	DR
12/18/2014	134178	5/8"	100%	100%	100%
12/18/2014	148250	5/8"	DR	DR	DR
12/18/2014	121222	5/8"	100%	100%	100%
12/18/2014	307176	5/8"	100%	100%	100%
12/18/2014	119070	5/8"	100%	100%	100%
12/18/2014	213130	5/8"	100%	100%	100%
12/12/2014	347194	5/8"	100%	100%	100%
12/12/2014	424142	1"	100%	100%	100%
12/12/2014	202038	5/8"	100%	100%	100%
12/12/2014	220133	5/8"	100%	100%	100%
12/10/2014	414245	3/4"	100%	100%	100%
12/10/2014	364255	5/8"	100%	100%	100%
12/10/2014	329249	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
12/8/2014	127107	5/8"	DR	DR	DR
12/8/2014	424221	5/8"	100%	100%	100%
12/8/2014	348039	5/8"	100%	100%	100%
12/5/2014	126076	3/4"	DR	DR	DR
12/5/2014	103244	3/4"	DR	DR	DR
12/5/2014	201024	5/8"	100%	100%	100%
12/5/2014	221212	5/8"	DR	DR	DR
12/5/2014	103030	5/8"	DR	DR	DR
12/5/2014	146035	5/8"	DR	DR	DR
12/5/2014	102043	5/8"	DR	DR	DR
12/5/2014	418218	5/8"	100%	100%	100%
12/5/2014	104229	5/8"	DR	DR	DR
12/5/2014	103298	3/4"	DR	DR	DR
12/4/2014	803918	5/8"	DR	DR	DR
12/4/2014	103099	5/8"	DR	DR	DR
12/4/2014	103109	5/8"	DR	DR	DR
12/3/2014	140265	1"	100%	100%	100%
11/26/2014	340146	5/8"	DR	DR	DR
11/25/2014	247199	5/8"	DR	DR	DR
11/25/2014	803769	5/8"	DR	DR	DR
11/25/2014	365043	5/8"	DR	DR	DR
11/24/2014	104226	5/8"	DR	DR	DR
11/24/2014	226185	5/8"	100%	100%	100%
11/24/2014	330191	5/8"	100%	100%	100%
11/24/2014	103053	5/8"	DR	DR	DR
11/21/2014	147190	5/8"	100%	100%	100%
11/21/2014	246146	5/8"	DR	DR	DR
11/21/2014	308169	5/8"	100%	100%	100%
11/20/2014	251408	1"	100%	100%	100%
11/20/2014	248200	5/8"	DR	DR	DR
11/20/2014	364042	5/8"	100%	100%	100%
11/20/2014	238234	5/8"	100%	100%	DR
11/19/2014	244169	3/4"	DR	DR	DR
11/19/2014	700242	2"	100%	100%	100%
11/18/2014	120044	5/8"	DR	DR	DR
11/18/2014	329148	5/8"	100%	100%	100%
11/18/2014	800248	5/8"	100%	100%	100%
11/18/2014	220145	5/8"	100%	100%	100%
11/18/2014	248206	5/8"	DR	DR	DR
11/18/2014	804043	5/8"	100%	100%	100%
11/17/2014	132173	5/8"	100%	100%	100%
11/17/2014	125063	5/8"	DR	DR	DR
11/17/2014	124066	5/8"	DR	DR	DR
11/14/2014	247088	3/4"	DR	DR	DR
11/12/2014	139254	5/8"	100%	100%	100%
11/12/2014	361175	3/4"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
11/12/2014	328084	5/8"	100%	100%	100%
11/12/2014	434010	5/8"	DR	DR	DR
11/12/2014	251041	5/8"	DR	DR	DR
11/12/2014	224198	5/8"	DR	DR	DR
11/12/2014	814742	3/4"	100%	100%	100%
11/7/2014	411178	5/8"	DR	DR	DR
11/7/2014	115097	5/8"	100%	100%	100%
11/7/2014	416161	5/8"	100%	100%	100%
10/31/2014	146134	5/8"	DR	DR	DR
10/31/2014	406023	5/8"	100%	100%	100%
10/30/2014	425119	1-1/2"	100%	100%	100%
10/29/2014	146167	5/8"	DR	DR	DR
10/28/2014	459019	5/8"	DR	DR	DR
10/28/2014	449050	5/8"	DR	DR	DR
10/28/2014	803905	3/4"	100%	100%	100%
10/28/2014	435129	5/8"	100%	100%	100%
10/28/2014	316246	5/8"	100%	100%	100%
10/28/2014	248170	5/8"	100%	100%	100%
10/24/2014	422073	5/8"	100%	100%	100%
10/24/2014	402304	5/8"	100%	100%	100%
10/24/2014	346083	5/8"	100%	100%	100%
10/24/2014	247158	5/8"	DR	DR	DR
10/23/2014	316292	5/8"	DR	DR	DR
10/23/2014	114102	5/8"	DR	DR	DR
10/23/2014	121005	5/8"	100%	100%	100%
10/23/2014	114115	5/8"	DR	DR	DR
10/22/2014	335129	5/8"	DR	DR	DR
10/22/2014	815263	3/4"	100%	100%	100%
10/21/2014	356119	5/8"	DR	DR	DR
10/21/2014	449217	5/8"	100%	100%	100%
10/21/2014	242106	5/8"	100%	100%	100%
10/21/2014	325124	5/8"	100%	100%	100%
10/21/2014	236167	5/8"	100%	100%	100%
10/21/2014	234023	5/8"	100%	100%	100%
10/20/2014	816607	5/8"	100%	100%	100%
10/20/2014	146081	5/8"	100%	100%	100%
10/20/2014	248085	5/8"	DR	DR	DR
10/20/2014	147213	5/8"	100%	100%	100%
10/16/2014	328282	5/8"	100%	100%	100%
10/16/2014	811446	5/8"	DR	DR	DR
10/9/2014	117022	5/8"	100%	100%	100%
10/9/2014	151028	5/8"	100%	100%	100%
10/9/2014	416254	5/8"	100%	100%	100%
10/8/2014	301078	5/8"	100%	100%	100%
10/8/2014	301245	5/8"	100%	100%	100%
10/8/2014	315249	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
10/8/2014	152040	5/8"	DR	DR	DR
10/8/2014	309120	3/4"	100%	100%	100%
10/6/2014	156160	5/8"	DR		
10/6/2014	102044	5/8"	DR		
10/6/2014	702233	1"	100%	100%	100%
10/3/2014	424182	2	100%	100%	100%
10/3/2014	318134	5/8"	100%	100%	100%
10/3/2014	354248	5/8"	DR		
10/3/2014	455007	5/8"	DR		
10/3/2014	417142	5/8"	100%	100%	100%
10/3/2014	423195	5/8"	100%	100%	100%
10/3/2014	334121	5/8"	100%	100%	100%
10/1/2014	817214	3/4"	100%	100%	100%
10/1/2014	462257	5/8"	100%	100%	100%
10/1/2014	417202	3/4"	100%	100%	100%
10/1/2014	223230	5/8"	100%	100%	100%
10/1/2014	219232	5/8"	100%	100%	100%
9/26/2014	811948	5/8"	100%	100%	100%
9/26/2014	149105	5/8"	DR		
9/23/2014	343177	5/8"	100%	100%	100%
9/18/2014	125134	1.5"	100%	100%	100%
9/16/2014	447132	5/8"	DR		
9/11/2014	345063	5/8"	100%	100%	100%
9/11/2014	462033	5/8"	100%	100%	100%
9/8/2014	817422	5/8"	DR		
9/8/2014	153111	5/8"	100%	100%	100%
9/8/2014	410069	5/8"	100%	100%	100%
9/8/2014	354253	1"	100%	100%	100%
9/8/2014	124128	5/8"	100%	100%	100%
9/4/2014	252054	5/8"	DR		
9/4/2014	355067	5/8"	DR		
9/4/2014	104035	5/8"	100%	100%	100%
9/2/2014	136104	5/8"	100%	100%	100%
8/28/2014	810831	5/8"	100%	100%	100%
8/22/2014	411168	5/8"	DR		
8/20/2014	104044	5/8"	100%	100%	100%
8/20/2014	701760	3/4"	100%	100%	100%
8/18/2014	221228	5/8"	100%	100%	100%
8/18/2014	439233	5/8"	100%	100%	100%
8/15/2014	702115	3/4"	100%	100%	100%
8/15/2014	108127	5/8"	100%	100%	100%
8/12/2014	313165	5/8"	100%	100%	100%
8/5/2014	106315	5/8"	100%	100%	100%
7/31/2014	151144	5/8"	DR		
7/28/2014	432228	5/8"	100%	100%	100%
7/28/2014	438113	3/4"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
7/23/2014	120044	5/8"	DR		
7/22/2014	125156	3/4"	DR		
7/22/2014	326048	2"	100%	100%	100%
7/21/2014	803249	5/8"	100%	100%	100%
7/21/2014	348062	5/8"	DR		
7/17/2014	455147	5/8"	100%	100%	100%
7/16/2014	113071	5/8"	100%	100%	100%
7/16/2014	803707	3/4"	100%	100%	100%
7/14/2014	811445	5/8"	DR		
7/14/2014	402216	5/8"	DR		
7/10/2014	352020	5/8"	100%	100%	100%
7/10/2014	346176	5/8"	100%	100%	100%
7/9/2014	425263	5/8"	100%	100%	DR
7/3/2014	224225	5/8"	DR		
7/2/2014	422367	3/4"	100%	100%	100%
6/30/2014	814671	3/4"	100%	100%	100%
6/30/2014	309268	3/4"	DR		
6/26/2014	338072	5/8"	100%	100%	100%
6/24/2014	147017	5/8"	100%	100%	100%
6/13/2014	157001	3/4"	DR		
6/13/2014	452149	5/8"	100%	100%	100%
6/13/2014	702402	3/4"	DR		
6/13/2014	101264	5/8"	100%	100%	100%
6/12/2014	409248	5/8"	DR		
6/4/2014	208011	5/8"	DR		
5/30/2014	127273	5/8"	100%	100%	100%
5/28/2014	301348	5/8"	100%	100%	100%
5/28/2014	324137	5/8"	100%	100%	100%
5/28/2014	817037	3/4"	100%	100%	100%
5/21/2014	250131	5/8"	100%	100%	100%
5/19/2014	242250	5/8"	100%	100%	100%
5/16/2014	104276	5/8"	100%	100%	100%
5/16/2014	455257	3/4"	DR		
5/16/2014	368189	5/8"	DR		
4/29/2014	344002	5/8"	100%	100%	100%
4/24/2014	453120	5/8"	DR		
4/23/2014	345141	5/8"	DR		
4/17/2014	224246	2"	100%	100%	100%
4/15/2014	461070	5/8"	DR		
4/11/2014	453119	5/8"	DR		
4/11/2014	453218	5/8"	100%	100%	100%
4/8/2014	409049	5/8"	DR		
4/4/2014	327010	5/8"	100%	100%	100%
4/2/2014	147078	5/8"	100%	100%	100%
4/2/2014	136166	5/8"	DR		
4/2/2014	136268	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
4/2/2014	422339	1"	100%	100%	100%
4/2/2014	436214	5/8"	100%	100%	100%
3/31/2014	206109	5/8"	100%	100%	100%
3/31/2014	810499	5/8"	DR		
3/27/2014	210231	5/8"	100%	100%	100%
3/27/2014	120093	5/8"	DR		
3/27/2014	468057	5/8"	100%	100%	100%
3/26/2014	218244	3/4"	DR		
3/26/2014	205088	5/8"	100%	100%	100%
3/25/2014	238190	5/8"	100%	100%	100%
3/25/2014	248183	5/8"	DR		
3/25/2014	103063	5/8"	100%	100%	100%
3/21/2014	357169	5/8"	100%	100%	100%
3/21/2014	210086	5/8"	DR		
3/21/2014	215038	5/8"	100%	100%	100%
3/20/2014	439115	5/8"	DR		
3/20/2014	243242	5/8"	100%	100%	100%
3/20/2014	321190	5/8"	100%	100%	100%
3/18/2014	810020	2"	100%	100%	100%
3/18/2014	346230	5/8"	DR		
3/18/2014	702056	3/4"	100%	100%	100%
3/12/2014	801238	5/8"	100%	100%	100%
3/12/2014	801965	5/8"	100%	100%	100%
3/11/2014	251276	5/8"	100%	100%	100%
3/6/2014	150041	5/8"	100%	100%	100%
2/28/2014	134102	5/8"	100%	100%	100%
2/28/2014	421032	5/8"	DR		
2/28/2014	802246	5/8"	100%	100%	100%
2/28/2014	101083	1"	DR		
2/28/2014	139205	5/8"	DR		
2/28/2014	208218	5/8"	100%	100%	100%
2/25/2014	449192	5/8"	100%	100%	100%
2/25/2014	125068	5/8"	DR		
2/25/2014	209026	5/8"	100%	100%	100%
2/25/2014	240211	5/8"	100%	100%	100%
2/25/2014	122239	5/8"	100%	100%	100%
2/14/2014	148146	5/8"	DR		
2/12/2014	153168	5/8"	100%	100%	100%
2/12/2014	103322	1"	100%	100%	100%
2/11/2014	323067	5/8"	100%	100%	100%
2/11/2014	463184	5/8"	100%	100%	100%
2/11/2014	351163	5/8"	100%	100%	100%
2/6/2014	443240	1.5"	100%	100%	100%
2/5/2014	429235	5/8"	100%	100%	100%
2/5/2014	468149	5/8"	100%	100%	100%
2/4/2014	438087	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
2/4/2014	410101	5/8"	100%	100%	100%
2/4/2014	411214	5/8"	100%	100%	100%
1/27/2014	234054	5/8"	DR		
1/27/2014	462115	5/8"	DR		
1/22/2014	804051	5/8"	100%	100%	100%
1/22/2014	430060	5/8"	100%	100%	100%
1/22/2014	112263	5/8"	100%	100%	100%
1/16/2014	143262	1"	100%	100%	100%
1/14/2014	409221	5/8"	DR		
1/14/2014	451143	3/4"	DR		
11/20/2013	348069	5/8"	100%	100%	100%
11/5/2013	813719	3/4"	100%	100%	100%
11/5/2013	800042	3/4"	100%	100%	100%
11/4/2013	449200	5/8"	DR		
10/31/2013	354073	5/8"	100%	100%	100%
10/31/2013	800419	5/8"	100%	100%	100%
10/31/2013	234049	5/8"	100%	100%	100%
10/17/2013	456105	5/8"	DR		
10/10/2013	437225	5/8"	100%	100%	100%
10/7/2013	248185	5/8"	DR		
10/7/2013	112081	5/8"	DR		
10/7/2013	419058	5/8"	DR		
10/7/2013	314271	3/4"	DR		
10/4/2013	234052	5/8"	DR		
10/4/2013	117079	5/8"	DR		
10/4/2013	360247	5/8"	DR		
10/4/2013	234056	5/8"	DR		
10/4/2013	147073	5/8"	100%	100%	100%
10/4/2013	225011	5/8"	DR		
9/27/2013	235281	5/8"	100%	100%	100%
9/27/2013	244227	5/8"	100%	100%	100%
9/27/2013	346242	5/8"	100%	100%	
9/24/2013	126034	5/8"	100%	100%	100%
9/24/2013	218085	5/8"	100%	100%	100%
9/24/2013	202081	3/4"	100%	100%	100%
9/18/2013	812755	1"	100%	100%	100%
9/17/2013	211058	5/8"	DR		
9/17/2013	230113	5/8"	DR		
9/17/2013	32264	5/8"	100%	100%	100%
9/10/2013	365078	5/8"	100%	100%	100%
9/10/2013	405269	5/8"	DR		
9/10/2013	342248	1"	100%	100%	100%
9/10/2013	112138	5/8"	100%	100%	100%
9/9/2013	148266	5/8"	100%	100%	100%
9/3/2013	331074	5/8"	100%	100%	100%
8/27/2013	112128	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
8/27/2013	467238	5/8"	DR		
8/26/2013	701361	2"	100%	100%	100%
8/23/2013	816838	5/8"	100%	100%	100%
8/20/2013	209009	5/8"	100%	100%	100%
8/20/2013	464021	5/8"	100%	100%	100%
8/20/2013	324171	5/8"	100%	100%	100%
8/20/2013	210152	5/8"	100%	100%	100%
8/16/2013	333028	5/8"	100%	100%	100%
8/7/2013	411169	5/8"	100%	100%	100%
8/6/2013	314249	5/8"	100%	100%	100%
8/6/2013	431006	5/8"	100%	100%	100%
8/6/2013	422135	5/8"	DR		
8/5/2013	323064	5/8"	100%	100%	100%
7/30/2013	157003	1.5"	100%	100%	100%
7/30/2013	425215	1"	100%	100%	100%
7/24/2013	237019	5/8"	DR		
7/24/2013	411167	5/8"	DR		
7/24/2013	813291	5/8"	100%	100%	100%
7/23/2013	420070	5/8"	100%	100%	100%
7/23/2013	355160	5/8"	DR		
7/17/2013	412215	5/8"	100%	100%	100%
7/17/2013	115034	5/8"	100%	100%	100%
7/17/2013	801784	5/8"	100%	100%	100%
7/11/2013	231102	5/8"	100%	100%	100%
7/11/2013	802276	5/8"	100%	100%	100%
7/10/2013	700821	1"	100%	100%	100%
7/3/2013	320288	5/8"	DR		
7/3/2013	454057	5/8"	DR		
7/3/2013	134159	5/8"	DR		
7/1/2013	205019	5/8"	100%	100%	100%
6/28/2013	814612	5/8"	DR		
6/28/2013	249250	5/8"	100%	100%	100%
6/28/2013	245817	5/8"	100%	100%	100%
6/28/2013	304268	3/4"	DR		
6/28/2013	454277	3/4"	100%	100%	100%
6/25/2013	224190	5/8"	DR		
6/25/2013	366012	5/8"	100%	100%	100%
6/25/2013	339288	1"	100%	100%	100%
6/21/2013	408212	5/8"	100%	100%	100%
6/21/2013	121042	5/8"	DR		
6/21/2013	209259	5/8"	DR		
6/19/2013	363077	5/8"	DR		
6/18/2013	454055	5/8"	DR		
6/18/2013	248256	1"	100%	100%	100%
6/11/2013	140081	5/8"	100%	100%	100%
6/11/2013	145206	5/8"	100%	100%	100%

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
6/11/2013	342173	5/8"	100%	100%	100%
6/11/2013	426084	1"	100%	100%	100%
6/7/2013	343090	5/8"	100%	100%	100%
6/7/2013	156178	3/4"	100%	100%	100%
6/7/2013	452142	3/4"	100%	100%	100%
6/7/2013	352081	5/8"	100%	100%	100%
6/7/2013	469078	5/8"	DR		
6/3/2013	207260	5/8"	100%	100%	100%
6/3/2013	144095	5/8"	100%	100%	100%
6/3/2013	460105	5/8"	DR		
5/23/2013	811805	3/4"	DR		
5/23/2013	316136	5/8"	100%	100%	100%
5/23/2013	115127	5/8"	DR		
5/23/2013	230053	5/8"	100%	100%	100%
5/21/2013	112133	5/8"	DR		
5/21/2013	102129	5/8"	DR		
5/21/2013	132005	5/8"	100%	100%	100%
5/21/2013	102129	5/8"	100%	100%	100%
5/20/2013	802855	3/4"	100%	100%	100%
5/20/2013	210032	5/8"	100%	100%	100%
5/20/2013	405033	5/8"	DR		
5/20/2013	112156	5/8"	DR		
5/20/2013	243050	3/4"	DR		
5/14/2013	80247	3/4"	100%	100%	100%
5/10/2013	145175	5/8"	100%	100%	100%
5/10/2013	405029	5/8"	DR		
5/8/2013	139118	5/8"	100%	100%	100%
5/8/2013	133175	5/8"	DR		
5/8/2013	224233	5/8"	DR		
5/3/2013	442132	3/4"	100%	100%	100%
5/2/2013	217003	5/8"	DR		
5/2/2013	348155	5/8"	100%	100%	100%
5/2/2013	241874	5/8"	100%	100%	100%
5/2/2013	242715	5/8"	100%	100%	100%
5/1/2013	149143	5/8"	100%	100%	100%
5/1/2013	242551	5/8"	100%	100%	100%
5/1/2013	452218	5/8"	100%	100%	100%
5/1/2013	405036	3/4"	DR		
4/25/2013	460031	5/8"	DR		
4/25/2013	327078	3/4"	DR		
4/24/2013	330237	5/8"	100%	100%	100%
4/24/2013	367214	5/8"	DR		
4/24/2013	814006	5/8"	100%	100%	100%
4/18/2013	323116	5/8"	100%	100%	100%
4/16/2013	248113	5/8"	100%	100%	100%
4/12/2013	308367	3/4"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
4/12/2013	801000	5/8"	100%	100%	100%
4/11/2013	800240	1"	100%	100%	100%
4/10/2013	360026	5/8"	100%	100%	100%
3/13/2013	153210	5/8"	100%	100%	100%
3/13/2013	319108	5/8"	100%	100%	100%
3/6/2013	443013	5/8"	100%	100%	100%
3/6/2013	205224	5/8"	100%	100%	100%
3/6/2013	227119	5/8"	DR		
3/6/2013	139150	5/8"	100%	100%	100%
3/1/2013	458068	5/8"	DR		
3/1/2013	358186	5/8"	100%	100%	100%
3/1/2013	156158	5/8"	DR		
2/25/2013	206226	5/8"	DR		
2/25/2013	239235	1.5"	100%	100%	100%
2/25/2013	324090	5/8"	100%	100%	100%
2/25/2013	360145	5/8"	DR		
2/25/2013	817927	3/4"	100%	100%	100%
2/15/2013	324090	5/8"	100%	100%	100%
2/13/2013	219002	3/4"	DR		
2/13/2013	243105	3/4"	100%	100%	100%
2/13/2013	441314	1"	100%	100%	100%
2/12/2013	220216	5/8"	100%	100%	100%
2/7/2013	440113	5/8"	DR		
2/7/2013	338080	5/8"	100%	100%	100%
2/7/2013	121109	5/8"	100%	100%	100%
2/4/2013	467121	5/8"	100%	100%	100%
2/4/2013	802785	3/4"	DR		
2/4/2013	410209	5/8"	DR		
2/4/2013	412099	5/8"	DR		
2/1/2013	418311	3/4"	100%	100%	100%
2/1/2013	426212	3/4"	100%	100%	100%
2/1/2013	360051	5/8"	100%	100%	100%
1/30/2013	138181	5/8"	100%	100%	100%
1/30/2013	235245	5/8"	DR		
1/30/2013	409044	5/8"	DR		
1/29/2013	155126	5/8"	100%	100%	100%
1/29/2013	336134	5/8"	DR		
1/29/2013	133038	5/8"	DR		
1/29/2013	802563	5/8"	DR		
1/29/2013	446056	5/8"	DR		
1/23/2013	439096	5/8"	DR		
1/23/2013	434024	5/8"	DR		
1/23/2013	325246	5/8"	100%	100%	100%
1/17/2013	814608	5/8"	DR		
1/17/2013	310241	5/8"	100%	100%	100%
1/11/2013	225044	5/8"	DR		

Date	Account Number	Meter Size	Slow Test	Medium Test	Fast Test
1/10/2013	455242	3/4"	100%	100%	100%
1/8/2013	332205	5/8"	DR		